



DRAFT RECOMMENDATION
OIML DR 117-1

Date: 9 February 2007

Supersedes document: OIML R 117-1
CD2

OIML TC 8 / SC 3

Title: Measuring Systems for Liquids other than Water - Part 1: Metrological and technical requirements

Clean version

Secretariat:

Mr. Ralph Richter – USA

Dr. Michael Rinker – Germany

Submitted for comments and preliminary postal ballot by CIGM Members

Deadline: 15 June 2007

TITLE OF THE DR (English):
Revision OIML R 117

Measuring Systems for Liquids other than Water –
Part 1: Metrological and technical requirements

TITLE OF THE CD (French):
Révision de OIML R 117

Systèmes de mesurage de liquides autres que l'eau –
Partie 1: Exigences métrologiques et techniques

Original version in: English

***** {Throughout the document, words and sections are that have been significantly revised since the second committee draft (2CD) of R117-1 are highlighted. Notes that explain some of the major changes are shown *[in italics and are inside square brackets]*. Both of these features are to assist in the review of the document and will be removed before the final publication of R117-1.}

CONTENTS

Explanatory note

Foreword

Terminology

1 Field of application

- 1.1 Scope
- 1.2 Liquids to be measured

2 General requirements

- 2.1 Constituents of a measuring system
- 2.2 Ancillary devices
- 2.3 Rated operating conditions
- 2.4 Accuracy classes
- 2.5 Maximum permissible errors and significant faults
- 2.6 Conditions for applying maximum permissible errors
- 2.7 Provisions for converted indications
- 2.8 Maximum permissible errors and significant faults on calculators
- 2.9 Indications
- 2.10 Elimination of air or gases
- 2.11 Gas indicator
- 2.12 Transfer point
- 2.13 Complete filling of the measuring system
- 2.14 Emptying of the delivery hose
- 2.15 Variations in the internal volume of full hoses
- 2.16 Branches and bypasses
- 2.17 Control and closing mechanisms
- 2.18 Various provisions
- 2.19 Markings
- 2.20 Sealing devices and stamping plate

3 Requirements for meters and ancillary devices of a measuring system

- 3.1 Meter
- 3.2 Indicating device
- 3.3 Price indicating device
- 3.4 Printing device
- 3.5 Memory device
- 3.6 Pre-setting device
- 3.7 Conversion device
- 3.8 Calculator

4 Measuring systems equipped with electronic devices

- 4.1 General requirements
- 4.2 Power supply device
- 4.3 Checking facilities

5 Requirements specific to certain types of measuring systems

- 5.1 Fuel dispensers
- 5.2 Measuring systems on road tankers
- 5.3 Measuring systems for the unloading of ships' tanks and of rail and road tankers using an intermediate tank
- 5.4 Measuring systems for liquefied gases under pressure (other than LPG dispensers)
- 5.5 Fuel dispensers for liquefied gases under pressure (LPG dispensers)
- 5.6 Measuring systems for milk, beer, and other foaming potable liquids
- 5.7 Measuring systems on pipelines and systems for loading ships
- 5.8 Measuring systems intended for the refuelling of aircraft
- 5.9 Blend dispensers
- 5.10 Self-service arrangements with fuel dispensers
- 5.11 Other self-service arrangements
- 5.12 Unattended delivery

6 Metrological control

- 6.1 Type approval
- 6.2 Initial verification
- 6.3 Subsequent verification

Annex A Type approval performance tests

- A.1 General
- A.2 Uncertainties of measurement
- A.3 Reference conditions
- A.4 Test volumes
- A.5 Influence of the liquid temperature
- A.6 Accuracy tests on a meter, a measuring device, or a meter sensor
- A.7 Endurance tests on a meter, a measuring device, or a meter sensor
- A.8 Accuracy tests on an electronic calculator
- A.9 Accuracy tests on conversion devices
- A.10 Influence factors tests on electronic devices
- A.11 Electrical disturbance tests
- A.12 Tests for power from road vehicle battery

Annex B Interpretation, examples, and possible solutions

EXPLANATORY NOTE

[This Explanatory Note section is a description of efforts and activities that were important in the revision of R117-1. This section will be edited and reduced in detail before final publication.]

A joint meeting of the OIML Subcommittees TC8/SC3 “*Dynamic volume measurement of liquids other than water*” and TC8/SC4 “*Dynamic mass measurement of liquids other than water*” was held in February 2000 in Paris. It was decided at this meeting to establish two new working groups to revise and merge OIML International Recommendations R105 and R117.

OIML TC8/SC3/WG2 “Revision of R117” was established to revise OIML International Recommendation R117 (Edition 1995), and OIML TC8/SC4/WG1 “Combination R105/R117” was established to make decisions on merging the two recommendations. Meeting participants agreed that the convenors of the two working groups should work closely together.

With respect to the numbering of the documents, it was agreed that a new R117-1 *Measuring Systems for Liquids other than Water, Part 1: Metrological and technical requirements* would be developed to replace and combine R105 (Edition 1993) and R117 (Edition 1995).

In December 2000, a questionnaire concerning drum meters for alcohol (OIML R86) was sent to all P- and O-members of TC8/SC3. It was decided from the response to not revise R86 and instead include these measuring systems in the revised R117-1. Then, R86 will be withdrawn.

In June 2001, all 25 P-Members of TC8/SC3 were invited to participate in TC8/SC3/WG2. Nineteen (19) P-Members agreed to participate in this working group; these same P-members also agreed to participate in TC8/SC4/WG1.

In May 2002, a first proposal for the revision of Annex A of R117, entitled “Performance Tests for Electronic Measuring Systems,” was sent for comment to the members of TC8/SC3/WG2.

Working Group TC8/SC4/WG1 accomplished its initial assignments in 2001 and 2002. During the course of these efforts, the group determined that it was extremely impractical to revise R105, a document that will be formally withdrawn after the project is complete. Instead, the working group concentrated on reviewing/analyzing the differences between the two documents and identifying “what needs to be changed” in R117 to accomplish the merger with R105.

To accelerate the work, the chairmen of the TC8/SC3 and TC8/SC4, plus the convenors of Working Groups TC8/SC3/WG2 and TC8/SC4/WG1 held an informal meeting in September 2002 at PTB in Braunschweig, Germany. Discussions at this meeting were based on a revised draft of R117. Many changes and additions to R117 were discussed, including the merger of R86 “Drum meters” into R117. The revised R117 will include measuring systems equipped with volumetric meters, turbine meters, electromagnetic meters, ultrasonic meters, vortex meters, drum meters, and mass flow meters. Efforts were made to avoid notes and the use of vague terminology wherever possible.

The first and second working drafts of R117 were developed and discussed by the working group convenors with the active participation of the national working groups of the United States of America and the Netherlands in the period of November 2002 to February 2003. A third working draft (WD3) was prepared, and in March 2003 the document was distributed to the international working groups (IWGs) for review and comment.

Over 540 comments were received from members of the IWGs on WD3. Many of these comments were lengthy, technical, and thoughtful -- often suggesting significant changes to entire sections of R117-1. The convenors worked diligently to respond to every single comment and make all appropriate changes and improvements to the next draft. Based on these received comments, the working group convenors prepared a first Committee Draft (1CD) and sent it to the members of the IWGs in August 2003. The 1CD was also sent in August 2003 to all participating and observing members of OIML TC8/SC3 and TC8/SC4 by the Secretariats of those two subcommittees.

A joint meeting of the two subcommittees was held from 6–9 October 2003. Hosted by the BIML at the Maison de la Chimie in Paris, the meeting was extremely productive and was very well attended by 45 participants, including official representatives from 17 Member States (17 P-Members of TC 8/SC 3 and 15 P-Members plus 2 O-Members of TC 8/SC 4). With participants from Japan, China, Australia, South Africa and Brazil, every continent was represented!

Working from the first committee draft of R117 (1CD, Aug 2003), participants successfully completed a lengthy and detailed agenda designed to resolve several key issues on the document's revision. The meeting was chaired by Dr. Detlev Mencke (of PTB/Germany) with assistance from Mr. Ralph Richter (of NIST/USA) and Mr. Aart Kooiman (of NMI/Netherlands). Several representatives of major manufacturers of these systems and liaison organizations also actively participated in the meeting, providing a valuable depth of experience and technical expertise. Most all discussions at the Paris meeting were lively and were followed by the reaching of general consensus by the meeting participants. A few issues on which there was a lack of clear consensus were voted upon by the quorum of subcommittee P-members.

Based on consensus decisions at the Paris meeting and other many comments received, the second committee draft (2CD) of R117-1 was sent to all participating and observing members of OIML TC8/SC3 and TC8/SC4 for vote and comment in April 2004. The 2CD received over 90% approval in voting from the two international subcommittees.

In October 2006, the CIML voted to merge TC 8/SC 3 and TC 8/SC 4 into one subcommittee. Mr. Ralph Richter (of NIST/USA) and Dr. Michael Rinker (of PTB/Germany) were named the co-secretariats of the merged subcommittee TC 8/SC 3 "Dynamic volume and mass measurement (liquids other than water)." TC 8/SC 4 was then disbanded.

The Draft Recommendation (DR) of R117-1 [this document] includes changes that are based upon over 95 pages of comments and suggested improvements to the 2CD. Major improvements to the R117-1 document include making the terminology section alphabetical and moving all testing requirements into Annex A. Efforts are already underway in TC 8/SC 3 to complete R117-2 "Test Methods" and R117-3 "Test Report Format."

Foreword

The International Organization of Legal Metrology (OIML) is a worldwide, intergovernmental organization whose primary aim is to harmonize the regulations and metrological controls applied by the national metrological services, or related organizations, of its Member States. The main categories of OIML publications are:

International Recommendations (OIML R), which are model regulations that establish the metrological characteristics required of certain measuring instruments and which specify methods and equipment for checking their conformity; the OIML Member States shall implement these Recommendations to the greatest possible extent;

International Documents (OIML D), which are informative in nature and intended to improve the work of the metrological services;

International Basic Publications (OIML B), which define the operating rules of the various OIML structures and systems;

International Guides (OIML G), which are informative in nature and which are intended to give guidelines for the application of certain requirements to legal metrology.

OIML Draft Recommendations, Documents and Guides are developed by Technical Committees or Subcommittees which are formed by the Member States. Certain international and regional institutions also participate on a consultation basis. Cooperative agreements are established between the OIML and certain institutions, such as ISO and the IEC, with the objective of avoiding contradictory requirements; consequently, manufacturers and users of measuring instruments, test laboratories, etc. may simultaneously apply OIML publications and those of other institutions.

International Recommendations, Documents and Guides are published in French (F) and English (E) and are subject to periodic revision.

Additionally, the OIML participates in the publication of **Vocabularies (OIML V)** and periodically commissions legal metrology Experts to write **Expert Reports (OIML E)**. Expert Reports are intended to provide information and advice to metrological authorities, and are written solely from the viewpoint of their author, without the involvement of a Technical Committee or Subcommittee, nor that of the CIML. Thus they do not necessarily represent the views of the OIML.

This publication - reference OIML DR 117-1, edition 2007 (E) - was developed by the OIML Technical Subcommittee TC 8/SC 3 *Dynamic volume and mass measurement (liquids other than water)*. It was approved for final publication by the International Committee of Legal Metrology in 200X and supersedes OIML R 117 edition 1995.

OIML Publications may be downloaded from the OIML web site in the form of PDF files. Additional information on OIML Publications may be obtained from the Organization's headquarters:

Bureau International de Métrologie Légale
11, rue Turgot - 75009 Paris - France
Telephone: 33 (0)1 48 78 12 82
Fax: 33 (0)1 42 82 17 27
E-mail: biml@oiml.org
Internet: www.oiml.org

TERMINOLOGY

Many of the definitions used in this Recommendation conform to the *International Vocabulary of Basic and General Terms in Metrology* (VIM – edition 1993), the *Vocabulary of Legal Metrology* (VML – edition 2000) and OIML International Document D 11 (published 2004). For the purposes of this Recommendation, the definitions below shall apply.

[The terminology section is especially important for users not that familiar with the document. The section has been re-formatted to be alphabetical].

T.a.1 Additional device

A part or a device, other than an ancillary device, required to ensure correct measurement or intended to facilitate the measuring operations, or which could in any way affect the measurement.

Main additional devices are:

- gas elimination device,
- gas indicator,
- sight glass,
- filter,
- pump,
- device used for the transfer point,
- anti-swirl device,
- branches or bypasses,
- valves, hoses.

T.a.2 Adjustment device

A device incorporated in the meter, that only allows shifting of the error curve generally parallel to itself, with a view to bringing errors within the maximum permissible errors.

T.a.3 Aircraft hydrant measuring system

A mobile measuring system intended for refuelling aircraft, supplied from hydrant pits.

T.a.4 Aircraft refuelling tanker measuring system

A mobile measuring system intended for refuelling aircraft, supplied from a tank mounted on the vehicle.

T.a.5 Ancillary device

A device intended to perform a particular function, directly involved in elaborating, transmitting or displaying measurement results.

Main ancillary devices are:

- zero setting device,
- repeating indicating device,
- printing device,
- memory device,
- price indicating device,
- totalizing indicating device,

- conversion device,
- pre-setting device,
- self-service device.

T.a.6 Associated measuring devices

Devices, connected to the calculator, the correction device or the conversion device, and converting, during the measurement the characteristic quantities (temperature, pressure, density, viscosity, etc.) of the liquid into signals aimed for the calculator, with a view to making a correction and/or a conversion. It includes an associated measuring sensor and an associated measuring transducer.

T.a.7 Associated measuring sensor

A part of the associated measuring device, directly affected by the measurand, which converts the characteristic quantity (temperature, pressure, density, viscosity, etc.) of the liquid into a measurement signal (resistance, electrical current, frequency, etc.) aimed for the associated measuring transducer.

T.a.8 Associated measuring transducer (See also T.t.1)

A part of the associated measuring device that provides an output quantity for the calculator, the correction device or the conversion device, and having a determined relationship to input quantity.

T.a.9 Authorization of a measuring system

An operation that brings the measuring system into a condition suitable for the commencement of the delivery.

T.a.10 Authorized person

A person that is allowed to perform specified activities on legally controlled measuring systems or components, under applicable national laws.

T.b.1 Blend dispenser

A fuel dispenser providing mixtures of various grades of a single product or blends of more than one product through a single nozzle; examples include gasoline (a multigrade-dispenser) and mixtures of gasoline and lubricating oil (a gasoline-oil-dispenser).

[Change made to allow for applications such as alternative fuels and biodiesel.]

T.c.1 Calculator

A part of the meter that receives the output signals from the measuring device(s) and, possibly, from associated measuring devices, processes them and, if appropriate, stores in memory the results until they are used. In addition, the calculator may be capable of communicating both ways with ancillary devices.

T.c.2 Checking facilities

A facility incorporated in a measuring system which:

- checks for the presence of a necessary device, and which
- enables an incorrectness in the generation, transmission, processing and/or indication of a measurement data to be detected and acted upon, and which
- enables significant faults to be detected and acted upon.

T.c.2.1 Automatic checking facility

A checking facility operating without the intervention of an operator.

T.c.2.2 Permanent automatic checking facility (type P)

An automatic checking facility operating during the entire measurement operation.

T.c.2.3 Intermittent automatic checking facility (type I)

An automatic checking facility operating at least once, either at the beginning or at the end of each measurement operation.

T.c.2.4 Non-automatic checking facility (type N)

A checking facility which requires the intervention of an operator.

T.c.4 Conditions

T.c.4.1 Base conditions

The specified values of the conditions to which the measured quantity of liquid is converted (example: base temperature and base pressure of the liquid).

Metering and base conditions (which refer only to the volume of liquid to be measured or indicated) should not be confused with the "rated operating conditions" and "reference conditions" which apply to influence quantities.

T.c.4.2 Metering conditions

The values of the conditions which characterize the liquid during measurement at the point of measurement (example: temperature and pressure of the liquid).

T.c.4.3 Rated operating conditions

Conditions of use, giving the range of values of influence quantities for which the metrological characteristics are intended to be within the maximum permissible errors.

T.c.4.4 Reference conditions

A set of specified values of influence factors fixed to ensure valid intercomparison of results of measurements.

T.c.5 Conversion device

A device, which automatically converts:

- the volume measured at metering conditions into a volume at base conditions, or
- the volume measured at metering conditions into a mass, or
- the measured mass into a volume at metering conditions, or
- the measured mass into a volume at base conditions, or
- the volume at metering conditions or the measured mass of a mixture of pure ethanol (ethyl alcohol) and water into a volume or the mass of pure ethanol contained in that mixture...

...by taking account of the characteristics of the liquid (temperature, pressure, density, relative density...) measured using associated measuring devices, or stored in a memory.

The ratio of the converted quantity to the quantity at metering conditions is referred to as the "conversion factor."

T.c.6 Correction device

A device connected to or incorporated in the meter for automatically correcting the measured quantity at the time of measurement, by taking into account the flowrate and/or the characteristics of the liquid to be measured (viscosity, temperature, pressure...) and the pre-established calibration curves.

The characteristics of the liquid shall either be measured using associated measuring devices, or stored in the memory of the instrument.

T.d.1 Deviations

T.d.1.1 Minimum specified quantity deviation

The absolute value of the maximum permissible error for the minimum measured quantity.

T.d.1.2 Minimum specified price deviation

The price to pay corresponding to the minimum specified quantity deviation.

T.d.2 Direct selling to the public (note in Annex B)

A sales transaction in which:

- the measurement result serves as the basis for the price to pay, and
- at least one of the parties involved in the transaction related to the measurement is a consumer or any other party requiring a similar level of protection, and
- all the parties in the transaction accept the measurement result obtained at that time and place.

T.d.3 Disturbance

An influence quantity having a value outside the specified rated operating conditions of the measuring system. (For electronic measuring systems only.)

If the rated operating conditions are not specified for an influence quantity, it is a disturbance.

T.d.4 Durability for electronic devices

The capability of the electronic devices of a measuring system to keep their performance characteristics over a period of use.

T.e.1 Empty hose measuring system

Empty hose systems are measuring systems in which the transfer point is located upstream of the delivery hose in measuring systems designed to deliver product (and downstream of the receiving hose in measuring systems designed to receive product).

T.e.2 Endurance

The capability of the measuring system to keep its performance characteristics over a period of use.

T.e.3 Endurance test

A test intended to verify whether the meter or the measuring system is able to maintain its performance characteristics over a period of use.

T.e.4 Errors

T.e.4.1 Error (of indication)

Indicated quantity value minus the reference (true) quantity value.

T.e.4.2 Relative error (of indication)

Error (of indication) divided by the reference (true) quantity.

T.e.4.3 Maximum permissible errors

The extreme values for an error permitted by this Recommendation.

T.e.4.4 Repeatability error

For the purposes of this Recommendation, the difference between the largest and the smallest results of successive measurements of the same quantity carried out under the same conditions.

T.e.4.5 Intrinsic error

The error (of indication) of a measuring system or its components used under reference conditions.

T.e.4.6 Initial intrinsic error

The intrinsic error as determined prior to all performance tests.

T.f.1 Significant fault

A difference between the error (of indication) and the intrinsic error greater than the value specified in this Recommendation. **Significant faults are only relevant to electronic measuring systems.**

The following are not considered to be significant faults:

- transitory malfunctions resulting in momentary variations in the indication, which cannot be interpreted, memorized, or transmitted as a measurement result,
- for interruptible measuring systems only, malfunctions implying the impossibility of performing further measurements.

[Definition for “fault” removed and all text uses of the word removed.]

T.f.2 Filter

A device suitable for protecting the meter and additional devices from being damaged by foreign particles

T.f.3 First element of an indicating device

Element which, in an indicating device comprising several elements, carries the graduated scale with the smallest scale interval.

T.f.4 Fuel dispenser

A measuring system intended for the refuelling of motor vehicles, small boats and small aircraft.

T.f.5 Full hose measuring system

Full hose systems are measuring systems in which the transfer point consists of a closing device located at or near the end of the delivery hose in measuring systems designed to deliver product (or near the beginning of the receiving hose in a measuring system designed to receive product).

T.g.1 Gas elimination device (see also Annex B)

A device used to remove any air, gas, or vapor contained in the liquid. There are several different types of air elimination devices, including gas separators, gas extractors, and special gas extractors. (Descriptions of these different types are discussed in Annex B.)

[definition for “Condenser Tank” moved to Annex B with other gas elimination devices]

T.g.2 Gas indicator

A device that allows easy detection of any air or gas bubbles that may be present in the liquid flow.

T.i.1 Indicating device (See also Annex B)

A part of the meter which displays the measurement results.

T.i.2 Influence quantity

A quantity which is not the subject of the measurement but which influences the value of the measurand or the indication of the measuring system.

T.i.3 Influence factor(*)

An influence quantity having a value within the rated operating conditions of the measuring system, as specified in this International Recommendation.

T.i.4 Interruptible and non-interruptible measuring system

An interruptible measuring system is a measuring system in which the liquid flow can be stopped easily and rapidly (this does not include an emergency stop). In other cases the measuring system is considered to be non-interruptible.

T.m.1 Measuring device

A part of the meter converting the flow, the volume or the mass of the liquid to be measured into signals, representing volume or mass, aimed for the calculator. It consists of a meter sensor and a transducer.

T.m.2 Measuring system

A system which is comprised of a meter for quantities (volume or mass) of liquids and its ancillary devices and additional devices.

T.m.3 Meter (for quantities (volume or mass) of liquids)

An instrument intended to measure continuously and display the quantity of liquid passing through the measuring device at metering conditions. A meter includes at least a measuring device, a calculator (including adjustment or correction devices if present) and an indicating device.

T.p.1 Payment

Monetary compensation in exchange for the delivered quantity of liquid.

T.p.1.1 Pre-payment

A type of payment requiring payment for a certain quantity of liquid before the delivery commences.

T.p.1.2 Post-payment or delayed payment

A type of payment requiring payment after the delivery, either before leaving the site (post-payment) or after leaving the site (delayed payment).

T.p.2 Performance test

A test intended to verify whether the equipment under test (EUT) is capable of accomplishing its intended functions.

T.p.3 Pre-setting device

A device which permits the selection of the quantity to be measured and which automatically stops the flow of the liquid at the end of the measurement of the selected quantity. The pre-set quantity may be the volume, the mass or the related price to pay.

T.p.4 Pipeline measuring system

A measuring system which in principle is installed on a fixed pipeline connecting two or more fixed tanks.

Such a pipeline is characterized by a flowrate of the liquid to be measured which, in general, either does not change or changes little during a prolonged period.

T.p.5 Power supply device

A device which provides the electronic devices with the required electrical energy, using one or several sources of a.c. or d.c.

T.p.6 Primary indications

One or more indications (displayed, printed or memorized) which are subject to legal metrology control.

T.p.7 Pump

A device which causes the liquid to flow through suction or pressure.

T.q.1 Quantities

T.q.1.1 True (reference) quantity

Total volume or mass that has passed through the meter during a measurement. Often referred to as “known quantity.”

T.q.1.2 Indicated quantity

Total volume or mass indicated by the meter.

T.q.1.3 Minimum measured quantity (MMQ)

The smallest quantity of liquid for which the measurement is metrologically acceptable for that system or element.

In measuring systems intended for delivering operations, this smallest quantity is referred to as the minimum delivery; in those intended for receiving operations, it is referred to as the minimum receipt.

T.s.1 Self-service arrangement

An arrangement that allows the customer to use a measuring system to obtain liquid without a second party intervention.

T.s.2 Self-service device

A specific device that is part of a self-service arrangement and which allows one or more measuring systems to perform in this self-service arrangement.

The self-service device includes all the elements and constituents that are mandatory so that a measuring system performs in a self-service arrangement.

T.s.3 Sensor or Meter sensor

A part of a measuring device, directly affected by the flow of the liquid to be measured and which converts the flow into a signal aimed for the transducer.

T.s.4 Service mode

T.s.4.1 Attended service mode

An operating mode of a self-service arrangement in which the supplier is present and controls the authorization for the delivery.

T.s.4.2 Unattended service mode

An operating mode of a self-service arrangement in which the self-service device controls the authorization for the delivery, based on an action of the customer.

T.s.5 Settlement of a transaction

A transaction is settled when the parties interested in the transaction have made their agreement known (explicitly or implicitly) as regards the amount of the transaction. This may be a payment, signing a credit card voucher, signing a delivery order, etc.

The parties interested in a transaction may be the parties themselves or their representatives (for example: the employee in a filling station, the driver of a truck)

T.s.6 Sight glass

A device for checking, before start-up and after shut-down, that all or part of the measuring system is either filled completely with liquid (full hose measuring systems) or completely empty of liquid (empty hose measuring system).

T.t.1 Transducer (See also T.a.8)

A part of the measuring device that provides an output signal, representing volume or mass, having a determined relationship to the input signal.

The transducer can either be incorporated with the meter sensor or be external to the meter sensor. In the latter case, it can be approved either with the sensor or with the calculator.

T.t.2 Transfer point

A point at which the liquid is defined as being delivered or received.

T.u.1 Uncertainty of the determination of an error (See also Annex B)

An estimate characterizing the range of values within which the true value of an error lies, including components due to the standard and its use, and components due to the verified or calibrated instrument itself.

MEASURING SYSTEMS FOR LIQUIDS OTHER THAN WATER

1 Field of application

1.1 Scope

This Recommendation specifies the metrological and technical requirements applicable to dynamic measuring systems for quantities (volume or mass) of liquids other than water subject to legal metrology controls. It also provides requirements for the approval of parts of the measuring systems (meter, etc.).

In principle, this Recommendation applies to all measuring systems fitted with a meter as defined in T.m.3 (continuous measurement), whatever be the measuring principle of the meters or their application, except:

- measuring systems for cryogenic liquids (OIML R 81),
- measuring systems for hot and cold potable water (OIML R 49)

This Recommendation is not intended to prevent the development of new technologies.

National or international regulations are expected to clearly specify which measuring systems for liquids other than water are subject to legal metrology controls.

For waste water it is up to the national authorities to decide if the use of measuring systems conforming to this Recommendation is mandatory, and which accuracy class is required.

1.2 Liquids to be measured

Measuring systems that are covered by this Recommendation may be used for the following liquids:

- liquid petroleum and related products: crude oil (and crude oil which may contain sediment and/or water), liquid hydrocarbons, liquefied petroleum gas (LPG), liquid fuel, lubricants, industrial oils, etc.;
- liquid food: dairy products (milk, cream, etc.), beer and brewer's wort, wine and musts (cider, etc.), alcoholic beverages (liquor, whiskey, etc.) non-alcoholic carbonated and not carbonated beverages, juices and concentrates, vegetable oils (soy-bean-oil, palm-oil, etc.);
- alcohol: pure ethanol (ethyl alcohol) and mixtures of only ethanol and water; chemical products in liquid state;
- “special water”: distilled water, deionised water, demineralised water and all water not covered by OIML R49-1 and OIML R 72;
- other liquids not listed.

2 General requirements

2.1 Constituents of a measuring system

A meter by itself is not a measuring system. The smallest possible measuring system shall include:

- a meter,
- a transfer point, and
- a hydraulic path with particular characteristics which must be taken into account.

For correct operation, it is often necessary to add:

- a gas elimination device,
- a filter,
- a pump, and
- correction devices

The measuring system may be provided with other ancillary and additional devices (see 2.2).

If several meters are intended for a single measuring operation, the meters are considered to form a single measuring system.

If several meters intended for separate measuring operations have common elements (calculator, filter, gas elimination device, conversion devices, etc.), each meter is considered to form a separate measuring system, sharing the common elements.

2.2 Ancillary devices

2.2.1 Ancillary devices may be a part of the calculator or of the meter, or may be a device connected through an interface to the calculator (for example).

As a rule these ancillary devices are optional. However, this Recommendation makes some of them mandatory, or prohibits some of them, for particular types of measuring systems. In addition, national or international regulations may make some of these devices mandatory in relation to the utilization of the measuring systems.

2.2.2 When these ancillary devices are mandatory in application of this Recommendation or of a national or international regulation, they are considered as integral parts of the measuring system, they are subject to control, and they shall meet the requirements of this Recommendation.

2.2.3 Non-mandatory ancillary devices which display a measurement result visible to the user, and which are not subject to control, shall bear a legend clearly visible to the user to indicate that they are not controlled. Printing devices may only be excluded from control if such a legend is present on each print-out intended for the customer. However, such a legend needs only be present on printouts truly intended for the customer (and not in all cases where the customer can have access to these printouts).

When ancillary devices are not subject to control, one shall verify that these devices do not affect the correct operation of the measuring system. In particular, the system shall continue to operate correctly and its metrological functions shall not be affected whether the ancillary device is connected or disconnected.

2.3 Rated operating conditions

2.3.1 The rated operating conditions of a measuring system are **defined** by the following characteristics:

- minimum measured quantity, MMQ
- flowrate range limited by the minimum flowrate, $Q_{\min}$, and the maximum flowrate, $Q_{\max}$,
- name or type of the liquid or its relevant characteristics, when an indication of the name or type of liquid is not sufficient to characterize the liquid, for example
 - o the relevant viscosity range limited by the minimum viscosity of the liquid, $\eta_{\min}$ and maximum viscosity of the liquid, $\eta_{\max}$,
 - o the density range limited by the minimum density of the liquid $\rho_{\min}$ and the maximum density of the liquid $\rho_{\max}$,
- the pressure range limited by the minimum pressure of the liquid, $P_{\min}$, and the maximum pressure of the liquid, $P_{\max}$,
- the temperature range limited by the minimum temperature of the liquid, $T_{\min}$ and the maximum temperature of the liquid, $T_{\max}$,
- Reynold's number range (if applicable), (where Reynold's number is indicated, the flowrate range need not be specified),
- severity levels which correspond to the climatic, electrical, and mechanical environment conditions to which the measuring system is designed to be exposed (see Annex A)
- nominal value of the AC voltage supply and/or limits of DC voltage supply

A measuring system shall exclusively be used for measuring liquids having characteristics within its rated operating conditions, as specified in the type approval certificate. The rated operating conditions of a measuring system shall be within the rated operating conditions of each of its constituent elements (meters, gas elimination devices).

[This paragraph was moved from Section 2.3.3.4.]

(Additional information on Section 2.3.1 is in Annex B.)

2.3.2 The minimum measured quantity of a measuring system shall have the form 1×10^n , 2×10^n or 5×10^n authorized units of volume or mass, where n is a positive or negative whole number, or zero.

The minimum measured quantity shall satisfy the conditions of use of the measuring system; except in exceptional cases, the measuring system shall not be used for measuring quantities less than this minimum measured quantity.

The minimum measured quantity of a measuring system shall be not less than the largest minimum measured quantity of any one of its constituent elements (meter(s), gas extractor(s), special gas extractor(s), etc.).

2.3.3 Flowrate range of a measuring system

2.3.3.1 The flowrate range of a measuring system shall be within the flowrate range of each of its elements.

2.3.3.2 The flowrate range shall satisfy the conditions of use of the measuring system; the latter shall be designed so that the flowrate is between the minimum flowrate and the maximum flowrate, except at the beginning and at the end of the measurement or during interruptions.

2.3.3.3 The ratio between the maximum and the minimum flowrate of the measuring system shall be:

- At least 10 for fuel dispensers, other than liquefied gases;
- At least 5 for other measuring systems.

Except for fuel dispensers, either for liquefied gases or not, this ratio may be less. In this case, the measuring system shall be fitted with an automatic checking device to detect when the flowrate of the liquid to be measured is outside the restricted flowrate range. This checking device shall be of type P and result in a visible or audible alarm for the operator; this alarm shall continue until the flowrate is within the restricted limits.

2.3.3.4 When two or more meters are mounted in parallel in the same measuring system, the limiting flowrates ($Q_{\max}$, $Q_{\min}$) of the various meters are taken into consideration, especially the sum of the limiting flowrates, to verify if the measuring system meets the provision above.

[first paragraph of Section 2.3.3.4 moved to Section 2.3.1]

2.4 Accuracy classes

Taking into consideration their field of application, measuring systems are classified into four accuracy classes according to Table 1.

Table 1

Class	Type of Measuring System
0.3	- Measuring systems on pipelines (see 5.7) (Without prejudice to what is stated for accuracy class 1.0 and 1.5)
0.5	All measuring systems if not differently stated elsewhere in this table, in particular: - fuel dispensers for motor vehicles (other than LPG dispensers) (see 5.1, 5.9, and 5.10) - measuring systems on road tankers for liquids of low viscosity (see 5.2) - measuring systems for the unloading of ships' tanks and rail and road tankers (see 5.3) - measuring systems for milk, beer, and other foaming liquids (see 5.6) - measuring systems for loading ships (see 5.7) - measuring systems for refuelling aircraft (see 5.8)
1.0	- Measuring systems for liquefied gases under pressure measured at a temperature equal to or above - 10 °C (see 5.4) - LPG dispensers for motor vehicles (see 5.5) - Measuring systems: • used for liquids whose dynamic viscosity is higher than 1000 mPa.s, or • whose maximum flowrate is not higher than 20 L/h or 20 kg/h
1.5	- Measuring systems for liquefied carbon dioxide (see 5.4.9), - Measuring systems (other than LPG dispensers) for liquefied gases under pressure measured at a temperature below - 10 °C (see 5.4)

A better accuracy for a certain type of measuring system may be specified.

2.5 Maximum permissible errors and significant faults (for mass and volume indications of the measuring system)

2.5.1 For quantities not smaller than two litres or two kilograms, and without prejudice to 2.5.3, the maximum permissible errors, positive or negative, on quantity indications (volume at metering conditions, volume at base conditions and/or mass) are specified in Table 2.

Table 2

Line	Accuracy classes			
	0.3	0.5	1.0	1.5
A (*)	0.3 %	0.5 %	1.0 %	1.5 %
B (*)	0.2 %	0.3 %	0.6 %	1.0 %
C (equal to Line A – Line B)	0.1 %	0.2 %	0.4 %	0.5 %

(*) see 2.6 for application of line A or line B.

2.5.2 For quantities smaller than two litres or two kilograms, and without prejudice to 2.5.3, the maximum permissible errors, positive or negative, on quantity indications (volume at metering conditions, volume at base conditions and/or mass) are specified in Table 3.

Table 3

Measured quantity	Maximum permissible errors
from 1 to 2 L or kg	value fixed in Table 2, applied to 2 L or kg
from 0.4 to 1 L or kg	twice the value fixed in Table 2
0.2 to 0.4 L or kg	twice the value fixed in Table 2, applied to 0.4 L or kg
from 0.1 to 0.2 L or kg	quadruple the value fixed in Table 2
less than 0.1 L or kg	quadruple the value fixed in Table 2, applied to 0.1 L or kg

The maximum permissible errors in Table 3 are related to line A or line B of Table 2 according to the requirements of 2.6

2.5.3 Whatever the measured quantity may be, the magnitude of the maximum permissible error is given by the greater of the following two values:

- the absolute value of the maximum permissible error given in Table 2 or Table 3, or
- the minimum specified quantity deviation, ($E_{\min}$).

For minimum measured quantities greater than or equal to two litres or two kilograms, the minimum specified quantity deviation ($E_{\min}$) is given by the following formulas:

> Formula for the measuring system:

$$E_{\min} = (2 \text{ MMQ}) \times (A/100)$$

where:

MMQ is the minimum measured quantity (volume or mass),

A is the numerical value specified in line A of Table 2 for the relevant accuracy class.

For MMQ less than two litres or two kilograms $E_{\min}$ is twice the value specified in Table 3, and related to line A of Table 2.

> Formula for the meter or measuring device:

$$E_{\min} = (2 \text{ MMQ}) \times (B/100)$$

where:

MMQ is the minimum measured quantity (volume or mass),

B is the numerical value specified in line B of Table 2 for the relevant accuracy class.

For MMQ less than two litres or two kilograms $E_{\min}$ is twice the value specified in Table 3, and related to line B of Table 2.

Note: $E_{\min}$ is an absolute maximum permissible error.

[inserted formula for the meter or measuring device was moved from Section 3.1.2.4]

2.5.4 The significant fault is greater than the larger of these two values:

- one fifth of the absolute value of the maximum permissible error for the measured quantity, or
- the minimum specified quantity deviation ($E_{\min}$) for the measuring system.

2.5.5 For measuring systems with accuracy class 0.3 or 0.5 and measuring liquids with a temperature less than $-10\text{ }^{\circ}\text{C}$ or above $+50\text{ }^{\circ}\text{C}$ the maximum permissible errors for accuracy class 1.0 shall be applied.

2.6 Conditions for applying maximum permissible errors

Provisions in this section apply to quantity indications at metering conditions (see 2.7 for converted indications).

2.6.1 Maximum permissible errors in line A of Table 2 apply to complete measuring systems, under rated operating conditions, without any adjustment between the various tests, for:

- type approval,
- initial verification ,
- subsequent verifications.

Note: If the meter is provided with an adjustment or correction device, for type approval, it is sufficient to verify that the error curve(s) is (are) within a range of two times the value specified in line A of Table 2.

2.6.2 Maximum permissible errors in line B of Table 2 apply to:

- type approval of a meter, under rated operating conditions, and
- verification of the meter before the initial verification of the measuring system.

Notes:

- 1) An adjustment is allowed for each liquid, but in this case the type approval certificate provides information on the capability of the meter to measure a particular liquid or group of liquids without particular precautions.
- 2) If the meter is provided with an adjustment or correction device, it is sufficient to verify that the error curve(s) is (are) within a range of two times the value specified in line B of Table 2 during type approval.

2.6.3 When stated in the type approval certificate, the initial verification of a measuring system intended to measure two or more liquids may be carried out with one liquid only or with a liquid different from the intended liquid(s). In this case and if necessary, the type approval certificate provides information concerning the maximum permissible errors to be applied, so that 2.6.1 is fulfilled by the measuring system for all intended liquids.

When stated in the type approval certificate, the verification of a meter before the initial verification of a measuring system intended to measure two or more liquids may be carried out with one liquid only or with a liquid different from the intended liquid(s). In this case and if necessary, the type approval certificate provides information concerning the maximum permissible errors to be applied, so that 2.6.2 is fulfilled by the meter for all intended liquids.

The above considerations may be extended to the case of a measuring system or a meter intended to measure only one liquid but verified with another liquid.

2.7 Provisions for converted indications

There are **two** approaches to verify a conversion device:

The first approach verifies the conversion device as part of a complete measuring system. In this approach, the associated measuring devices, the calculator, and the indicating device are verified together. This approach applies to mechanical conversion devices and may apply to electronic conversion devices.

The second approach allows for verification of a conversion device, or its separate components, other than as part of a complete measuring system. This approach allows the **separate** verification of associated measuring sensors, associated measuring devices (made up of an associated measuring sensor plus an associated measuring transducer), and the conversion device (as part of the calculator with its indicating device).

In both of these approaches, for the purpose of the verification, the indication of the quantity at metering conditions is assumed to be without any error.

The approach to be applied shall be specified by the applicant for type approval.

2.7.1 First Approach: Verification of a conversion device as part of a complete measuring system

2.7.1.1 It is not mandatory that a conversion device indicates the quantities measured by the associated measuring devices (such as temperature, pressure, and density).

2.7.1.2 When a conversion device is verified as part of the complete measuring system with which it is intended to be used, the MPE allowable on the converted indication due to the conversion device (positive or negative), is the greater of:

- the value specified in line C of Table 2, or
- one half of the minimum specified quantity deviation ($E_{\min}$).

2.7.1.3 The value of a significant fault on converted indications (from 2.5.4) is the greater of:

- one fifth of the absolute value of the MPE for the measured quantity, or
- the minimum specified quantity deviation ($E_{\min}$).

2.7.2 Second Approach: Verification of a conversion device or its separate components (other than as part of a complete measuring system)

2.7.2.1 Verification of a conversion device (as part of the calculator with its indicating device), using simulated inputs

2.7.2.1.1 Using digital input signals: when a calculator with its indicating device is verified separately, using known “digital input signals” to simulate inputs from associated measuring devices, the MPE and the significant fault for the indication of the temperature or pressure or density are restricted to rounding errors.

2.7.2.1.2 Using analog input signals: when a calculator with its indicating device is verified separately, using known “analog input signals” to simulate inputs from associated measuring devices, the MPE and the significant fault for the indication of the temperature or pressure or density are those specified in Table 4.1.

Table 4.1 MPE for converted indications with known simulated analog inputs

Maximum permissible errors (MPE), and Significant faults, on measuring:	Accuracy class of the measuring system			
	0.3	0.5	1.0	1.5
Temperature	± 0.18°C	± 0.30 °C		
Pressure	Less than 1 MPa : ± 30 kPa between 1 and 4 MPa : ± 3 % more than 4 MPa : ± 120 kPa			
Density (mass to volume conversion)	± 0.6 kg/m ³		± 1.2 kg/m ³	
Density (temp. or pressure conversion)	± 3 kg/m ³			

Note: See 3.7.6 for determination of the size of scale intervals on associated measuring devices.

2.7.2.1.3 Verification of indications of converted quantities using simulated inputs

The indication of the converted quantity shall agree with the “true value”, within one tenth of the MPE stated in line A of Table 2 for the applicable accuracy class. The “true value” is calculated based on the quantities indicated for the simulated inputs for the following:

- \$ the unconverted quantity
- \$ the temperature or pressure or density as determined by associated measuring devices as well as:
- \$ any characteristic quantities entered into the calculator (typically density) and
- \$ appropriate values from applicable International Recommendations and Standards

2.7.2.2 Verification of associated measuring devices or associated measuring sensors

2.7.2.2.1 The MPE and significant fault for indications of temperature or pressure or density measured by an associated measuring device (which is made up of an associated measuring sensor and an associated measuring transducer) when it is subjected to a known temperature or pressure or density, are those specified in Table 4.2. If the indication is provided by the conversion device (as part of the calculator with its indicating device), this MPE includes the MPE of the corresponding calculator as specified in 2.7.2.1.1.

2.7.2.2.2 When an associated measuring device, which provides a digital signal output is verified by subjecting it to a known temperature or pressure or density, the MPE and significant fault are those specified in Table 4.2. The rounding errors of the calculator or other indicating device are assumed to be negligible.

2.7.2.2.3 When an associated measuring sensor (which provides an analog output) is verified separately by subjecting it to a known temperature or pressure or density, the MPE and significant fault are those specified in Table 4.3.

Table 4.2, MPE for associated measuring device indications

Maximum permissible errors (MPE), and Significant faults, on measuring:	Accuracy class of the measuring system			
	0.3	0.5	1.0	1.5
Temperature	± 0.30°C	± 0.50 °C		
Pressure	Less than 1 MPa : ± 50 kPa between 1 and 4 MPa : ± 5 % more than 4 MPa : ± 200 kPa			
Density (mass to volume conversion)	± 1.0 kg/m ³		± 2.0 kg/m ³	
Density (temp. or pressure conversion)	± 5 kg/m ³			

Note: See 3.7.6 for determination of the size of scale intervals on associated measuring devices.

Table 4.3, MPE for the output signal of the associated measuring sensors

Maximum permissible errors (MPE), and Significant faults, on measuring:	Accuracy class of the measuring system			
	0.3	0.5	1.0	1.5
Temperature	± 0.24°C	± 0.40°C		
Pressure	Less than 1 MPa : ± 40 kPa between 1 and 4 MPa : ± 4 % more than 4 MPa : ± 160 kPa			
Density (mass to volume conversion)	± 0.8 kg/m³		± 1.6 kg/m³	
Density (temp. or pressure conversion)	± 4 kg/m³			

Note: See 3.7.6 for determination of the size of scale intervals on associated measuring devices.

2.8 Maximum permissible errors and significant faults on calculators

Maximum permissible errors and significant faults on quantities of liquid indications applicable to calculators, positive or negative, when they are tested separately, are equal to one-tenth of the maximum permissible error defined in line A of Table 2. However, the magnitude of the maximum permissible error, respectively significant fault, shall not be less than one half of the scale interval of the measuring system in which the calculator is intended to be included.

2.9 Indications

2.9.1 The volume shall be indicated in cubic centimetres or millilitres, in cubic decimetres or litres, or in cubic metres. The mass shall be indicated in grams, kilograms, or tons.

The name of the unit or its symbol shall appear in the immediate vicinity of the indication. For mass, according to the case, the name of the unit or its symbol shall be accompanied by the term “mass” (actual mass) or “conventional mass” (comparison to weights).

Where units of quantity are delivered by associated measuring instruments: temperature shall be indicated in degrees Celsius or in degrees Kelvin, density shall be indicated in kilograms per cubic meter, and pressure shall be indicated in bars or Pascal.

If units of measurement outside the SI are required by a country's national regulations, these units of measurement shall be considered acceptable for indications in that country. In international trade, the officially agreed equivalents between these units of measurement and those of the SI shall be applied.

[Text changes based on comments from Germany, France, and the Netherlands]

2.9.2 Measuring systems shall be provided with an indicating device giving the quantity of liquid measured at metering conditions.

When a measuring system is fitted with a conversion device, it shall be possible to indicate the quantity at metering conditions and the converted quantity.

The use of the same display for the indications of quantities at metering conditions and converted indications is permitted provided that the nature of the displayed quantity is clear and that these indications are available on request. (See also Annex B.)

Provisions applicable to devices which indicate the quantity at metering conditions apply to devices which indicate the converted quantities by analogy.

2.9.3 A measuring system may have several devices indicating the same quantity. Each shall meet the requirements of this Recommendation. Scale intervals of the various indications may be different.

2.9.4 For any measured quantity relating to the same measurement, the indications provided by various devices shall not deviate one from another by more than one scale interval or the greatest of the two scale intervals if they differ, except otherwise provided in clause 5 (see 5.10.1.3).

For totalizers this requirement applies to the difference in indication before and after the measurement.

2.9.5 Subject to specific provisions for certain types of measuring systems, use of the same indicating device for the indications of several measuring systems (which then have a common indicating device) is permitted provided that one of the following conditions is met:

- it is impossible to use any two of these measuring systems simultaneously,
- the indications relating to a given measuring system are accompanied by a clear identification of that measuring system and the user may obtain the indication corresponding to any of the measuring systems concerned, using a simple command.

2.10 Elimination of air or gases

2.10.1 General requirements

Measuring systems shall incorporate a gas elimination device for the proper elimination of any air or undissolved gases which may be contained in the liquid before it enters the meter. In the case that neither air intake nor gas release will occur in the liquid upstream of the meter, a gas elimination device is not required.

The gas elimination device shall be suitable for the supply conditions and be arranged in such a way that the effect due to the influence of the air or gases on the measuring result does not exceed:

- 1 % of the quantity measured for milk, beer, other foaming potable liquids, and for liquids of a viscosity exceeding 1 mPa.s (at 20 °C); or
- 0.5 % of the quantity measured for all other liquids.

However, it is not necessary for this effect to be less than 1 % of the minimum measured quantity.

The values specified in this section apply to the difference between:

- the meter errors with air intake or with gas, and
- the meter errors without air intake or gas.

Gas elimination devices shall be installed in accordance with the manufacturer's instructions.

[This sentence moved from Section 2.10.2 as a general requirement.]

2.10.2 Pumped flow

A gas elimination device is required when the pressure at the pump inlet may, even momentarily, fall below either the atmospheric pressure or the saturated vapor pressure of the liquid.

A gas elimination device is also required when the pressure at the pump inlet is always greater than the atmospheric pressure and the saturated vapour pressure of the liquid, but gaseous formations liable to have a specific effect greater than 1 % of the minimum measured quantity can occur. When applying this provision concerning gaseous formations, it is important to consider that:

- gaseous formations are likely to occur because of thermal contraction during shutdown periods; and
- air pockets are likely to be introduced into the pipe work when the supply tank becomes empty.

No gas elimination device is required if the pressure at the pump inlet is always greater than the atmospheric pressure and the saturated vapour pressure of the liquid, and if any gaseous formation liable to have a specific effect greater than 1 % of the minimum measured quantity cannot form or enter the inlet pipe work of the meter, whatever the conditions of use.

If the gas elimination device is installed below the level of the meter, a non-return valve shall be incorporated to prevent the pipework between the two components from emptying.

The loss of pressure caused by the flow of liquid between the gas elimination device and the meter shall be as small as possible.

If the pipework upstream of the meter incorporates several high points, it may be necessary to provide one or more automatic or manual evacuation devices.

2.10.3 Non-pumped flow

When a meter is supplied by gravity without use of a pump, and if the pressure of the liquid in all parts of the pipe work upstream of the meter and in the meter itself is greater than the saturated vapor pressure of the liquid and the atmospheric pressure at metering conditions, a gas elimination device is not necessary.

If the pressure of the liquid is likely to be lower than the atmospheric pressure while remaining greater than the saturated vapor pressure, an appropriate automatic device shall prevent entry of air into the meter.

In other cases, an appropriate gas elimination device shall be provided.

If a meter is supplied under gas pressure, the measuring system shall be so constructed that release of gas dissolved in the liquid is avoided. An appropriate device shall prevent entry of gas into the meter.

In all circumstances, the pressure of the liquid between the meter and the transfer point shall be greater than the saturated vapor pressure of the liquid.

2.10.4 Viscous liquids

Since the effectiveness of gas elimination devices decreases as the viscosity of the liquids increases, these devices are not required for measuring liquids with a dynamic viscosity of more than 20 mPa.s at 20 °C.

In this case, it is necessary to make provisions to prevent entry of air. The pump shall be so arranged that the inlet pressure is always greater than the atmospheric pressure.

If it is not always possible to meet this condition, a device shall be provided to stop the flow of liquid automatically as soon as the inlet pressure falls below the atmospheric pressure. A pressure gauge shall be used to monitor this pressure. These provisions are not necessary if devices are provided which ensure that no air can enter through the joints in the sections of the pipework under reduced pressure and if the measuring system is so arranged that no air or dissolved gases will be released.

2.10.5 Gas removal pipe

The gas removal pipe of a gas elimination device shall not include a manually-controlled valve. However, if such a closing element is required for safety reasons, it shall be possible to ensure that the valve remains in the open position during operation by means of a sealing device or by means of a system interlock that would prevent further measurement upon valve closure.

2.10.6 Anti-swirl device

If the supply tank of a measuring system is normally to be completely emptied, the outlet of the tank shall be fitted with an anti-swirl device, unless the measuring system incorporates a gas separator.

2.10.7 General provisions for gas elimination devices

2.10.7.1 The gas separated in a gas elimination device shall be evacuated automatically unless a device is provided which automatically either stops or sufficiently reduces the flow of liquid when there is a risk of air or gases entering the meter. In the case of shutdown, no measurement shall be possible unless the air or gases are automatically or manually eliminated.

2.10.7.2 The operational limits of a gas elimination device are as follows:

- the maximum flowrate(s) for one or more specified liquids,
- the maximum pressure (with no flow running) and minimum pressure (with liquid and without air intake while the pump is running at maximum flowrate) compatible with the correct operation of the gas elimination device, and
- the minimum measured quantity for which it is designed.

2.10.8 Special provisions applicable to gas separators

Within the error limits specified in 2.10.1, a gas separator shall ensure the elimination of air or gases mixed with the liquid. A gas separator designed for a maximum flowrate lower than or equal to 20 m³/h shall ensure the elimination of any proportion by volume of air or gases relative to the measured liquid. A gas separator designed for a maximum flowrate higher than 20 m³/h shall ensure the elimination of 30 % air or gases relative to the measured liquid (the volumes of air or gases are measured at atmospheric pressure in determining their percentages). The percentage is considered only when the meter is running at flow rates higher than the minimum flow rate (mean value during one minute).

[Paragraph edited to be read as general requirements – and not test procedures.]

Furthermore, when provided, the automatic gas elimination device must continue to operate at the maximum pressure fixed for the gas separator.

2.10.9 Special provisions applicable to gas extractors

A gas extractor shall, at the maximum flowrate of the measuring system, ensure the elimination of an air or gas pocket of a volume (measured at atmospheric pressure) at least equal to the minimum measured quantity with no resulting additional effect greater than 1 % of the minimum measured quantity.

A special gas extractor (capable of eliminating mixed gas and gas pockets), shall also be capable, at the systems maximum flowrate, of continuously separating a volume of air or gas mixed with the liquid equal to 5 % of the volume of liquid delivered (at the maximum flowrate) without the resulting additional effect exceeding the limits fixed in 2.10.1.

2.11 Gas indicator

For certain types of measuring systems a gas indicator may be required.

The gas indicator shall be designed so as to provide a satisfactory indication of the presence of air or gases in the liquid.

The gas indicator shall be downstream of the meter. In empty hose measuring systems, the gas indicator may be in the form of a weir-type sight glass and may also be used as the transfer point.

The gas indicator may be fitted with a bleed screw or with any other venting device when it forms a high point of the pipe work. No pipe shall be connected to the venting device. Flow indicating devices (e.g. spinners) may be incorporated in gas indicators provided that such devices do not prevent observation of any gaseous formations which could be present in the liquid.

2.12 Transfer point

2.12.1 Measuring systems shall incorporate a minimum of one transfer point. This transfer point is located downstream of the meter in delivery systems and upstream of the meter in receiving systems.

2.12.2 Measuring systems may be of two types: "empty hose" systems and "full hose" systems: the term "hose" includes rigid pipe work.

2.12.2.1 In case of an empty hose system the transfer point may be in the form of either a weir type sight glass, or a closing device combined, in each case, with a system which ensures the emptying of the delivery hose after each measuring operation.

2.12.2.2 When, in case of full hose systems, the delivery line has a free end, the closing device must be installed as close as possible to this end.

2.12.2.3 In the case of receiving equipment, the same provisions apply by analogy to the reception pipe work upstream of the meter.

2.13 Complete filling of the measuring system

2.13.1 The meter and the pipe work between the meter and the transfer point shall be kept full of liquid during measurement and during shutdown periods.

When this condition is not met, especially in the case of fixed installations, the complete filling of the measuring system up to the transfer point shall be effected manually or automatically and monitored during measurement and shutdowns. To ensure complete elimination of air and gases from the measuring system a venting device, with means for visual or automatic detection of the complete filling, shall be placed in appropriate positions.

2.13.2 The effect of contraction due to temperature change on the liquid in the pipe work between the meter and the transfer point shall not be greater than 1 % of the minimum measured quantity due to variations in temperature, equal to:

- 10 °C for exposed pipes,
- 2 °C for insulated or underground pipes.

To calculate this additional effect the coefficient of thermal expansion for the liquid shall be rounded to 1×10^{-3} per degree Celsius.

2.13.3 Following the provisions in 2.10.3, a pressure maintaining device shall, if necessary, be installed downstream of the meter to ensure that the pressure in the gas elimination device and in the meter is always greater than both the atmospheric pressure and the saturated vapour pressure of the liquid.

2.13.4 When reversal of the flow could result in errors greater than the minimum specified quantity deviation, a measuring system (in which the liquid could flow in the opposite direction when the pump is stopped) shall be provided with a non-return valve. If necessary, the system shall also be fitted with a pressure limiting device

2.13.5 In empty hose measuring systems, the pipe work downstream of the meter and, if necessary, the pipe work upstream of the meter shall have a high point so that all parts of the measuring system except the hose, always remain full.

2.13.6 In full hose measuring systems which are used for measuring liquids other than liquefied gases, the free end of the hose shall incorporate a device which prevents the draining of the hose during shutdown periods.

When a closing device is installed downstream of this device, the volume of the space between them shall be as small as possible and, in all cases, be less than the minimum specified quantity deviation.

2.13.7 If the hose comprises several components, these shall be assembled either by means of a special connector which keeps the hose full, or by a connection system which is either sealed or requires the use of a special tool to be disconnected.

2.14 Emptying of the delivery hose

In empty hose measuring systems, emptying of the delivery hose referred to in 2.12.2.1 is ensured by a venting valve. In some cases, this valve may be replaced by an active means, such as an auxiliary pump or compressed gas injector. This active device shall operate automatically.

However, when it is not possible, for duly established technical or safety reasons, to deliver (or to receive) the measured quantity contained in hoses of an empty hose measuring system (for example when measuring liquefied carbon dioxide), this quantity shall be smaller than or equal to half the minimum specified quantity deviation.

2.15 Variations in the internal volume of full hoses

For full hoses in a measuring system provided with a hose reel, the increase in internal volume due to the change from the coiled hose position when not under pressure to the uncoiled hose position when under pressure without any flow of liquid, shall not exceed twice the minimum specified quantity deviation.

If the measuring system is not provided with a hose reel, the increase in internal volume shall not exceed the minimum specified quantity deviation.

2.16 Branches and bypasses

2.16.1 In measuring systems intended to deliver liquids, no means shall be provided by which any measured liquid can be diverted downstream of the meter. However, two or more delivery outlets may be permanently installed and operated simultaneously or alternately provided so that any diversion of flow to other than the intended receiving receptacle(s) cannot be readily accomplished or is readily apparent. Such means include, for example, physical barriers, visible valves or indications that make it clear which outlets are in operation, and explanatory signs, if necessary.

For measuring systems intended to receive liquids, such provisions apply by analogy.

A manually controlled outlet may be available for purging or draining the measuring system. Effective means shall be provided to prevent the passage of liquid through any such outlet during normal operation of the measuring system.

2.16.2 In measuring systems which may operate either with an empty hose or with a full hose and which are equipped with flexible pipes, a non-return valve shall be incorporated in the rigid pipework leading to the full hose immediately downstream from the selector valve. In addition, the selector valve shall not, in any position, permit connection of the discharge hose, operating as an empty hose to the pipework leading to the full hose.

2.16.3 It shall not be possible to bypass the meter in normal conditions of use.

2.17 Control and closing mechanisms

2.17.1 If there is a risk that the supply conditions can overload the meter, a flow limiting device shall be provided. This device shall be installed downstream of the meter. It shall be possible to seal it.

2.17.2 The various positions of the controls of multi-way valves shall be easily visible and located by notches, stops or other fixing devices. Deviations from this requirement are permissible when the adjacent positions of the controls form an angle of 90° or more.

2.18 Various provisions

2.18.1 If provided, filters shall not disturb the accuracy or operation of the measuring system or its components.

2.18.2 In the case of measuring liquid petroleum products, means for vapor recovery shall not influence the accuracy of measurements such that the maximum permissible error is exceeded.

2.18.3 It may be possible in meters for liquid food (for example milk) to dismount and disassemble the measuring device to the extent necessary for cleaning. The measuring device must be designed such that improper assembly of the components of the measuring device is not possible. Instead, the meters may be provided with assembly instructions or marks that will ensure correct measurements.

Dismounting the measuring device shall not provide the ability to change the accuracy of the device, and in particular, it shall not provide access to sealed parameters or other adjustment means.

2.19 Markings

2.19.1 Each measuring system shall bear the following information:

- type approval number
- manufacturer's identification mark, trademark or name
- designation selected by the manufacturer, if appropriate
- year of manufacture
- serial number
- characteristics as defined in section 2.3.1 (measuring system), 3.1.1.1 (meter), or 2.10.7.2 (gas elimination device),
- accuracy class,
- verification marks.

This information shall be put on one or several data plates on a part not likely to be removed in normal conditions of use.

At least the information related to the minimum measured quantity and the verification marks shall be visible in normal conditions of use.

The information marked on the measuring system shall be the information based on the type approval, including the temperature range of the liquid, and should not be confused with descriptions affixed for safety reasons, in particular the pressure limits.

2.19.2 Each component or sub-system for which type approval has been granted shall bear the following information:

- Serial number
- Type approval number

This information shall be part of the component or sub-system itself or shall be put on a data plate not likely to be removed from the component or sub-system under normal conditions of use.

2.19.3 If several components operate in a single measurement system, the markings required for each part of the system may be combined on a single plate.

If several separate measuring systems operate in a common housing, only one data plate is required.

When a measuring system can be transported without being dismantled, the markings required for each component may also be combined on a single plate.

2.19.4 When volume at base conditions is indicated, the result of measurement shall be accompanied with information with respect to the base conditions, for example:
“at 15 °C” or “at 15 °C and 101.325 kPa”.

2.20 Sealing devices and stamping plate

2.20.1 General

Sealing may be carried out with metal, plastic or other suitable means as long as it is sufficiently durable and provides evidence of tampering

The seals shall, in all cases, be easily accessible.

Sealing shall be provided on all parts of the measuring system which cannot be materially protected in any other way against operations liable to affect the measurement accuracy.

Without prejudice to the provisions in 3.1.4 and **3.7.5**, it must be prohibited to change parameters which participate in the determination of the results of measurement (parameters for correction and conversion in particular) by means of sealing devices.

A plate, referred to as the stamping plate, aimed at receiving the verification marks, shall be sealed or permanently attached on a support of the measuring system. It may be combined with the data plate of the measuring system referred to in 2.19.

In the case of a measuring system used for potable liquids, sealing shall be applied such that the equipment may be dismantled for cleaning purposes.

2.20.2 Electronic sealing devices

[Note for the DR of R117:

Section 2.20.2 has been extensively re-written based inputs from many sources.]

2.20.2.1 When access to parameters that participate in the determination of results of measurement is not protected by mechanical sealing devices, the protection shall fulfil the provisions of Sections 2.20.2.1.1 through 2.20.2.1.5.

2.20.2.1.1 Either:

- Access shall only be allowed to authorized persons, e.g. by using a “password” and, after changing parameters, the measuring system may be put into use “in sealed condition” again without any restriction; or
- Access is allowed without restrictions (similar with the classical sealing) but, after changing parameters, the measuring system shall only be put into use “in sealed condition” again by authorized persons, e.g. by using a “password.”

2.20.2.1.2 The “password” must be changeable.

2.20.2.1.3 In case of direct selling to the public, the use of only a “password” is not allowed and the measuring system shall be provided with a mechanical sealing device, e.g. access cover protected switch or key switch.

2.20.2.1.4 When it is in the configuration mode (a mode in which parameters can be changed), the device shall either: not operate or clearly indicate that it is in the configuration mode. This status shall remain until the measuring system has been put into use “in sealed condition” in accordance with 2.20.2.1.1.

2.20.2.1.5 For identification, data concerning the latest intervention(s) shall be automatically recorded into an event logger. The record shall include at least:

- an event counter,
- the date the parameter was changed (this is allowed to be entered manually),
- the new value of the parameter, and
- an identification of the person that implemented the intervention

The traceability of the last intervention shall be assured for at least two years, if it is not overwritten on the occasion of a further intervention.

Given the current state of technology, it is strongly encouraged that the event logger store many more than just one intervention. If more than one intervention is stored, and if deletion of a previous intervention must occur to permit a new record, the oldest record shall be deleted.

2.20.2.2 For measuring systems with parts which may be disconnected one from another by the user and which are interchangeable, the following provisions shall be fulfilled:

- it shall not be possible to access parameters that participate in the determination of results of measurements through disconnected points unless the provisions in 2.20.2.1 are fulfilled;
- interposing any device which may influence the accuracy shall be prevented by means of electronic and data processing securities or, if not possible, by mechanical means.

2.20.2.3 For measuring systems with parts which may be disconnected one from another by the user and which are not interchangeable, the provisions in 2.20.2.2 apply. Moreover, these measuring systems shall be provided with devices which do not allow them to operate if the various parts are not associated according to the manufacturer's configuration.

Note: Disconnections which are not allowed to the user may be prevented, for example by means of a device that prevents any measurement after disconnecting and reconnecting.

3 Requirements for meters and ancillary devices of a measuring system

3.1 Meter

The meter(s) of a measuring system shall meet the following requirements, whether or not it (they) is (are) subject to a separate type approval:

3.1.1 Rated operating conditions

3.1.1.1 The rated operating conditions of a meter are determined at least by the following characteristics:

- minimum measured quantity, MMQ;
- flowrate range limited by the minimum flowrate, $Q_{\min}$, and the maximum flowrate, $Q_{\max}$, (or by the Reynolds number range, if applicable);
- name or type of the liquid or its relevant characteristics, for example the viscosity range limited by the minimum viscosity of the liquid and the maximum viscosity of the liquid and/or the density range limited by the minimum density of the liquid $\rho_{\min}$ and the maximum density of the liquid $\rho_{\max}$;
- the pressure range limited by the minimum pressure of the liquid, $P_{\min}$ and the maximum pressure of the liquid, $P_{\max}$;
- the temperature range limited by the minimum temperature of the liquid, $T_{\min}$, and the maximum temperature of the liquid, $T_{\max}$;
- climatic and mechanical environmental class (see Annex A);
- nominal value of the AC voltage supply and/or limits of DC voltage supply.

3.1.1.2 The value of the minimum measured quantity shall be in the form 1×10^n , 2×10^n or 5×10^n authorized units of volume or mass, n being a positive or negative whole number, or zero.

3.1.2 Metrological requirements

In this section, the requirements for a meter also apply to measuring devices (see 6.1.5).

3.1.2.1 The maximum permissible errors for a meter, under rated operating conditions, are equal to those specified in line B of Table 2.

3.1.2.2 For any quantity equal to or greater than five times the minimum measured quantity, the repeatability error of the meter shall not be higher than two-fifths of the value specified in line A of Table 2.

3.1.2.3 Under rated operating conditions for a given liquid, meters shall present a magnitude of the difference between the initial intrinsic error and the error after the endurance test equal to or less than the value specified in line B in Table 2.

3.1.2.4 The minimum specified quantity deviation ($E_{\min}$) for the meter is given by the second formula in Section 2.5.3.

[the deleted contents of Section 3.1.2.4 were moved to Section 2.5.3]

3.1.3 Adjustment device

A meter may have a sealable means of adjustment which permits modification of the ratio between the indicated quantity and the actual quantity to be within:

- 0.05 % for meters intended for measuring systems with accuracy class 0.3;
- 0.1 % for meters intended for measuring systems with all other accuracy classes.

An adjustment device shall only be used to reduce the errors to as close to zero as possible. Adjustment by means of a bypass of the meter is prohibited.

3.1.4 Correction device

3.1.4.1 Meters may be fitted with correction devices; such devices are always considered as an integral part of the meter. The whole of the requirements which apply to the meter, in particular the maximum permissible errors specified in 3.1.2.1, are therefore applicable to the corrected quantity (at metering conditions).

3.1.4.2 In normal operation, the non-corrected quantity shall not be displayed. The non-corrected quantity shall, however, be available for test purposes.

3.1.4.3 The correction device shall only be used to reduce the errors to as close to zero as possible.

3.1.4.4 All the parameters which are not measured and which are necessary for correcting shall be contained in the calculator at the beginning of the measurement operation. The type approval certificate may prescribe the possibility of checking parameters that are necessary for correctness at the time of verification of the correction device.

3.1.4.5 For transactions that involve direct selling to the public, applying a correction is allowed only by selecting the name or the type of the liquid at the beginning of the measurement operation.

For transactions that do not involve direct selling to the public, it is allowed to select or enter the name or type of the liquid or any other data, when this data participates in the correction of the quantity. This other allowed data are those that characterize the name or type of the measured liquid without any ambiguity.

All cases are subject to the following conditions:

- A printing device subject to legal metrological control is mandatory.
- This data and a note explaining that this data has been entered manually shall be printed at the same time as the measuring results
- The name or type of the liquid shall be known and printed without any ambiguity.

For transactions that do not involve direct selling to the public (especially transactions governed by specific contracts), a printing device is not required when the following conditions exist:

- when the correction is stored by a memory device accessible to all parties involved, or
- when both parties have the possibility to be present to conclude the transaction, by any appropriate means, and the two parties are informed of the conditions of the correction.

The type approval certificate may indicate how to gain access to the memorized data.

[Changes in Section 3.1.4.5 are based on comments from 7 countries.]

3.1.4.6 The correction device shall not allow the correction of a pre-estimated drift in relation to time or total quantity, for example.

3.1.4.7 The associated measuring devices, if any, shall comply with the applicable International Standards or Recommendations. Their accuracy shall be good enough to permit the requirements on the meter be met, as specified in 3.1.2.1.

3.1.4.8 Associated measuring devices shall be fitted with checking facilities, as specified in 4.3.6.

3.1.5 Measuring systems equipped with turbine meters

3.1.5.1 The pressure downstream of the meter shall be such that cavitation is avoided.

3.1.5.2 If the accuracy of the meter is affected by disturbances in the upstream or downstream pipeline, the meter shall be provided with a sufficient number of straight pipe lengths, with or without flow straightening devices, as specified by the manufacturer, so that the indications of the installed measuring system including the meter meet the requirements of 2.4 to 2.6 with respect to the maximum permissible errors and according to the accuracy class of the measuring system.

3.1.5.3 The characteristics of the flow straightening devices, and/or straight pipe lengths, if required, shall be specified in the type approval certificate.

3.1.5.4 If the system is provided with a programmable or adjustable “low-flow cut-off” feature, the low-flow cut-off value shall not be set at flow rates higher than 20% of the application defined minimum flow rate of the meter.

[A discussion in Paris included a proposal to add this paragraph (3.1.5.4) into 3.1.5 because the low flow cut-off feature is applicable to all meters. Previously, this feature was only discussed in connection with mass flowmeters. There was also a proposal to change to a higher percentage of Q_{min} (maybe 20%). In the 2CD, the convenors decided to retain the 1CD text. However, based on a comment from Germany and further consultations, these changes have now been made. In sections 3.1.6 to 3.1.9, requirements have been changed to reference Sections 3.1.5.1 through 3.1.5.4.]

3.1.6 Measuring systems equipped with electromagnetic meters

3.1.6.1 The requirements in 3.1.5.1 to 3.1.5.4 apply.

3.1.6.2 The rated operating conditions with respect to the conductivity of the liquid and the cable characteristics shall be specified by the manufacturer and shall be documented in the type approval certificate.

3.1.6.3 The error caused by the maximum zero-offset of the electromagnetic meter at the minimum flow rate during one minute shall not exceed the minimum specified quantity deviation ($E_{\min}$).

[This requirement, originally from the section for mass flowmeters (2CD), is also applicable to electromagnetic meters.]

3.1.7 Measuring systems equipped with ultrasonic meters

3.1.7.1 The requirements in 3.1.5.1 to 3.1.5.4 apply.

3.1.7.2 The minimum Reynolds number of the liquid to be measured shall be specified by the manufacturer.

3.1.7.3 The error caused by the maximum zero-offset of the ultrasonic meter at the minimum flow rate during one minute shall not exceed the minimum specified quantity deviation ($E_{\min}$).

[This requirement, originally from the section for mass flowmeters (2CD), is also applicable to ultrasonic meters.]

3.1.8 Measuring systems equipped with vortex meters

3.1.8.1 The requirements in 3.1.5.1 to 3.1.5.4 and the requirement in 3.1.7.2 apply.

3.1.9 Measuring systems equipped with mass flowmeters

3.1.9.1 The requirements in 3.1.5.1 to 3.1.5.4 apply.

3.1.9.2 The mass flow meter shall be installed in the measuring system in accordance with system manufacturer's recommendations and with any conditions or limitations set out in the type approval certificate.

3.1.9.3 For verification purposes, the mass flow meter shall be equipped with features to perform the zero flow setting under condition of no flow. These features shall be sealed.

3.1.9.4 The error caused by the maximum zero-offset of the mass flow meter at the minimum flow rate during one minute shall not exceed the minimum specified quantity deviation ($E_{\min}$).

3.1.10 Measuring systems equipped with drum meters for alcohol

3.1.10.1 The volume of the individual measuring chambers of the drum meter shall be 1×10^n , 2×10^n or 5×10^n litres, where n is a positive or negative whole number, or zero. The chambers of the drum shall be of equal size.

The drum axis shall be horizontal. In order to be able to ensure that it is correctly installed, the meter shall be equipped with a level indicating device if, when the drum axis is inclined up to 3° to the horizontal, the indication of the meter varies by more than half the maximum permissible error on verification.

3.1.10.2 The volumes of the individual measuring chambers of a drum meter may be adjusted by means of displacement bodies. The associated conversion device which measures the density and the temperature of the measured liquid shall be adjustable.

3.1.10.3 The conversion device to determine the volume of ethanol belonging to a drum meter shall function in accordance with the International Recommendation OIML R 22 “International alcoholometric tables” (1975). The reference temperature for the alcohol measurement is 20 °C. The conversion may be applied mechanically or electronically.

3.1.10.4 The sampler of a drum meter shall automatically separate and collect a representative sample of the liquid to be measured in order to permit the separate determination of the average alcohol content of liquid, which has passed through the measuring device, for example, by separating an equal volume each time the measuring chambers are filled.

If the test volume withdrawn is subject to special or separate treatment, the measuring device shall be so adjusted that the volume withdrawn is not included in the indication of the drum meter.

3.1.10.5 The elimination of air intake or gas release will be performed by the drum meter itself. So no additional gas elimination device is required.

3.1.10.6 The following inadmissible operating conditions and failures of a drum meter shall either be prevented by special devices incorporated in the meter, or their occurrences shall be indicated by warning devices:

- excessive flowrate,
- obstruction of free flow,
- overfilling of the drum due to obstruction of the rotating elements,
- temperature outside the permissible range,
- inadmissible heating of the separated sample.

[Section on “Measuring systems for mass flowmeters is now Section 3.1.9]

3.2 Indicating device

3.2.1 General provisions

3.2.1.1 Reading of the indications shall be precise, easy and non-ambiguous whatever position the indicating device comes to rest; if the device comprises several elements, it shall be arranged in such a way that the reading of the measured quantity can be made by simple juxtaposition of the indications of the different elements. The decimal sign shall appear distinctly.

3.2.1.2 The scale interval shall be in the form 1×10^n , 2×10^n or 5×10^n authorized units of quantity, where n is a positive or negative whole number, or zero.

3.2.1.3 Non-significant minimum increments of registration should be avoided. This does not apply to price indications.

3.2.1.4 The scale interval shall satisfy the following requirements:

- for analog indicating devices, the quantity corresponding to 2 mm on the scale or to one-fifth of the scale interval (of the first element for mechanical indicating devices), whichever is greater, shall be less than or equal to the minimum specified quantity deviation;
- for digital indicating devices, the quantity corresponding to two minimum increments of registration shall be less than or equal to the minimum specified quantity deviation.

3.2.2 Mechanical indicating device

3.2.2.1 When the graduation of an element is entirely visible, the value of one revolution of that element shall be in the form 10^n authorized units of quantity, where n is a whole number. This rule however, does not apply to the element corresponding to the maximum range of the indicating device.

3.2.2.2 On an indicating device having several elements, the value of each revolution of an element whose graduation is entirely visible must correspond to the scale interval of the following element.

3.2.2.3 An element of the indicating device may have continuous or discontinuous movement, but when elements other than the first have only part of their scales visible through the windows, these elements shall have discontinuous movement.

3.2.2.4 The advance by one figure of any element having discontinuous movement shall occur and be completed when the preceding element passes from 9 to 0.

3.2.2.5 When the first element has only a part of its scale visible through a window and has a continuous movement, the dimension of that window shall be at least equal to 1.5 times the distance between two consecutive graduated scale marks.

3.2.2.6 All scale marks shall have the same width, constant along the line and not exceeding one quarter of the scale spacing. The apparent scale spacing shall be equal to or greater than 2 mm. The apparent height of the figures shall be equal to or greater than 4 mm, unless otherwise specified in the requirements for particular measuring systems.

3.2.3 Electronic indicating device

The continuous display of quantity during the period of measurement is only mandatory in the case of direct selling to the public. However, if interrupting the display of quantity interrupts the action of some checking facilities that are mandatory or necessary to ensure correct measurement, the quantity passing through the meter during each interruption shall be smaller than or equal to the minimum measured quantity.

If the device is capable of hiding a small number of "minimum increments of registration" at the beginning of a measurement, it must be possible during type approval and initial verification to easily switch off this feature.

3.2.4 Zero setting device for the quantity indicating device

3.2.4.1 A quantity indicating device may be provided with a ancillary device for setting the indication to zero either by manual operation or by means of an automatic system.

3.2.4.2 Once the zeroing operation has begun it shall be impossible for the quantity indicating device to show a result different from that of the measurement which has just been made, until the zeroing operation has been completed.

Indicating devices on fuel dispensers and electronic measuring systems shall not be capable of being reset to zero during measurement. On other measuring systems, either this provision shall be fulfilled or a clearly visible notice shall be provided on the indicating device stating that this operation is prohibited.

3.2.4.3 On analog indicating devices, the residual indication after return to zero shall not be more than half the minimum specified quantity deviation.

3.2.4.4 On digital indicating devices, the quantity indication after return to zero shall be zero without any ambiguity.

3.2.4.5 In case of direct selling to the public, and except for fuel dispensers, the following provisions apply:

- The next delivery shall be inhibited until the indicating device has been reset to zero, or
- When the zeroing operation is not automatic, the measuring system shall bear a legible and indelible information inviting the customer to reset the indication before the delivery.

3.3 Price indicating device

3.3.1 A quantity indicating device with aligned figures and zero setting may be complemented with a price indicating device, also with aligned figures and zero setting.

3.3.2 The unit price may be displayed before the delivery (3.3.2.1) or the unit price may be keyed in after the delivery (3.3.2.2).

3.3.2.1 The selected unit price shall be displayed by an indicating device before the start of the measurement (unless the option in Section 3.3.2.2 is used). The unit price shall be adjustable; changing the unit price may be carried out either directly on the measuring system or through ancillary devices.

The indicated unit price at the start of the measurement operation shall be valid for the whole transaction. A new unit price shall only be effective at the moment of a new measurement operation.

A time of at least 5 seconds shall elapse between indicating a new unit price and before the next measurement operation can start, if the unit price is set from ancillary devices.

3.3.2.2 (This section is not applicable to fuel dispensers.) In the case of price indicating devices for measuring systems other than fuel dispensers, it is permitted to display only the quantity before and during the delivery. Neither unit price nor total price is displayed before and during the delivery. After the measurement operation is complete, the unit price is selected (or keyed in) to process the total price calculation to conclude the transaction; this unit price shall be valid for the whole transaction.

In case of direct selling to the public, the unit price shall be displayed or printed.

[Changes to Section 3.3.2.2 based on proposals by France and South Africa.]

3.3.3 The provisions in 3.2 relating to quantity indicating devices apply also, by analogy, to the price indicating devices.

3.3.4 The monetary unit used, or its symbol, shall appear in the immediate vicinity of the indication.

3.3.5 The zero setting devices of the price indicating device and of the quantity indicating device shall be designed in such a way that zeroing either indicating device automatically involves zeroing the other.

3.3.6 The scale interval shall satisfy the following requirements

- for analog indicating devices, the price corresponding to 2 mm on the scale or to one-fifth of the scale interval (of the first element for mechanical indicating devices), whichever is greater, shall be less than or equal to the minimum specified price deviation;
- for digital indicating devices, the price corresponding to two minimum increments of registration, shall be less than or equal to the minimum specified price deviation.

However, the interval of one-fifth of the scale interval or of 2 mm in the case of the first bullet or the scale interval in the case of the second bullet needs not correspond to a value less than that of the smallest coin in circulation in the country in which the equipment is used.

3.3.7 The difference between the indicated price and the price calculated from the unit price and the indicated quantity shall not exceed the minimum specified price deviation. However this difference need not be less than the smallest coin in circulation in the country in which the equipment is used.

Moreover, this requirement does not apply when the unit price has been changed between two measurements.

3.3.8 The significant fault on price indication (the difference in 3.3.7) is the price corresponding to the significant fault for the quantity as specified in section 2.5.4.

3.3.9 On analog indicating devices, the residual indication after zeroing shall not exceed half the minimum specified price deviation. However, this indication need not be less than the smallest coin in circulation in the country in which the equipment is used.

3.3.10 On digital indicating devices, the price indication after zeroing shall be zero without any ambiguity.

3.4 Printing device

3.4.1 The printed scale interval shall be in the form of 1×10^n , 2×10^n or 5×10^n authorized units of quantity, n being a positive or negative whole number, or zero, and shall not be greater than the minimum specified quantity deviation.

The printed scale interval shall not be less than the smallest scale interval of the indicating devices.

3.4.2 The quantity printed shall be expressed in one of the units authorized for the indication of quantity and expressed in the same units as the indicating device.

The figures, the unit used or its symbol and the decimal sign, if any, shall be printed unambiguously on the ticket.

3.4.3 The printing device may also print information identifying the measurement such as: sequence number, date, identification of the dispenser, type or name of liquid, etc.

If the printing device is connected to more than one measuring system, it shall print the identification of the relevant system.

3.4.4 If a printing device allows repetition of the printing before a new delivery has started, copies shall be clearly marked as such, for example by printing "duplicate".

3.4.5 If the quantity is determined by the difference between two printed values, even if one is expressed in zeros, it shall be impossible to withdraw the ticket from the printing device during measurement.

3.4.6 Where the printing device and quantity indicating device each have a zeroing device, these devices shall be designed so that resetting one of them to zero also resets the other.

3.4.7 The printing device may print, in addition to the measured quantity, the corresponding transaction price, or this price accompanied by the unit price.

Any value shall be printed as a repeated value from the measuring system.

The figures, the monetary unit used or its symbol, and the decimal sign, if any, shall be printed unambiguously on the ticket

3.4.8 The printed price scale interval shall be in the form 1×10^n , 2×10^n or 5×10^n monetary units, n being a positive or negative whole number, or zero; it shall not exceed the minimum specified price deviation. However, it need not be less than the smallest coin in circulation in the country in which the equipment is used.

3.4.9 If the quantity indicating device is not fitted with a price indicating device, the difference between the printed price and the price calculated on the basis of the indicated quantity and the printed unit price shall comply with the requirements in 3.3.7.

3.4.10 Electronic printing devices are also subject to the requirements in 4.3.5.

3.5 Memory device

3.5.1 Measuring systems may be fitted with a memory device to store measurement results until their use or to keep a record of commercial transactions, providing proof in case of a dispute. Devices used to read stored information are considered as included in the memory devices.

It is not required that the parties interested in a transaction shall be provided continuously with the results of measurement, but only that they shall have access to these results (for example, in case of a dispute).

In addition, in the case of self-service (filling station, truck filling station) the owner of the measuring system is considered to have access to the indications of the measuring system even when he does not use this possibility in practice.

3.5.2 The medium on which data are stored must have sufficient permanency to ensure that the data are not corrupted under normal storage conditions. There shall be sufficient memory storage for any particular application.

3.5.3 Stored data may be deleted if either:

- the transaction is settled, or
- these data are printed by a printing device subject to legal control.

3.5.4 After Section 3.5.3 requirements are fulfilled and when the storage is full, it is permitted to delete memorized data when both the following conditions are met:

- data are deleted in the same order as the recording order and the rules established for the particular application are respected,
- deletion is carried out after a special manual operation.

3.5.5 Memorization shall be such that it is impossible in normal use to modify stored values.

The data memorized must be protected against unintentional and intentional changes with common software tools.

3.5.6 Memory devices shall be fitted with checking facilities according to 4.3.5. The aim of the checking facility is to ensure that stored data correspond to the data provided by the calculator and that restored data correspond to stored data.

3.6 Pre-setting device

3.6.1 The preset quantity shall be indicated before the start of the measurement.

3.6.2 Where pre-setting is effected by means of several controls which are independent of each other, the scale interval corresponding to one control shall be equal to the pre-setting range of the control of the next lower order.

Pre-setting devices with push-buttons or similar means to pre-set fixed quantities are allowed, provided that these fixed quantities are equal to a whole number of units of volume or mass.

3.6.3 Pre-setting devices may be so arranged that the repetition of a selected quantity does not require a new setting of the controls.

3.6.4 Where it is possible to view simultaneously the figures of the display device of the pre-setting device and those of the quantity indicating device, the former shall be clearly distinguishable from the latter.

3.6.5 Indication of the selected quantity may, during measurement, either remain unaltered or return progressively to zero. However, for an electronic pre-setting device it is acceptable to indicate the preset value on the indicating device for quantity or price by means of a special operation with the restriction that this value shall be replaced by the zero indication for quantity or price before the measurement operation can start.

3.6.6 In the case of a prepaid or pre-ordered delivery:

- the difference found under normal operating conditions between the pre-set quantity and the quantity shown by the quantity indicating device at the end of the measurement operation shall not exceed the minimum specified quantity;
- the difference found under normal operating conditions between the prepaid amount and the price shown by the price indicating device at the end of the measurement operation shall not exceed the minimum specified price deviation.

3.6.7 The pre-set quantities and the quantities shown by the quantity indicating device shall be expressed in the same unit. This unit (or its symbol) shall be marked on the pre-setting mechanism.

3.6.8 The scale interval of the pre-setting device shall not be less than the scale interval of the indicating device.

3.6.9 Pre-setting devices may incorporate a device to permit the flow of liquid to be stopped quickly when necessary.

3.6.10 Measuring systems with a price indicating device may also be fitted with a price pre-setting device which stops the flow of the liquid when the quantity delivered corresponds to the pre-set price. The requirements in 3.6.1 to 3.6.9 apply by analogy.

3.7 Conversion device

3.7.1 Measuring systems may be fitted with a conversion device as defined in T.1.12. The provisions of Section 3.7 apply to electronic conversion devices and, by analogy, to mechanical conversion devices.

3.7.2 The calculation of the converted quantity shall be made according to the applicable International Recommendations or Standards, or other acceptable methods.

3.7.3 The parameters which characterize the measured liquid and which are employed in the conversion formula shall be measured using associated measuring devices subject to control when the parameters vary during the measurement process. However, some of these parameters may be not measured, or associated measuring devices may be not subject to control if these parameters do not vary substantially. In any case, the maximum permissible errors on converted indications due to the conversion device, shall not exceed the values specified in section 2.7.1.2.

3.7.4 Associated measuring sensors and suitable provisions for testing shall be installed within a distance of one metre (1 m) of the meter wherever possible. Where this is not possible, it shall be possible to verify that the associated measuring devices are able to determine (within the maximum permissible errors as defined in Table 4.2) the relevant characteristic quantities of the liquid, as they exist in the measuring device.

The associated measuring devices shall not affect the correct functioning of the meter(s).

3.7.5 All the parameters which are not measured and which are necessary for the conversion shall be present in the calculator at the beginning of the measurement operation. It must be possible to print or to indicate them from the calculator.

For a mechanical conversion device that cannot print or indicate these values, a seal must be broken to change any setting.

For direct selling to the public, it is allowed to enter the name or type of the liquid into the calculator at the beginning of the measurement operation; it is not permitted to change any other parameter participating in conversion unless a seal is broken.

In other cases, it is allowed to select or enter the name or type of the liquid or any other data, when this data participates in the conversion of the quantity, subject to the following conditions:

- A printing device subject to legal metrological control is mandatory
- This data and a note explaining that this data has been entered manually shall be printed at the same time as the measuring results.
- The name or type of the liquid shall be known and printed without any ambiguity.
- Where the transaction does not involve direct selling to the public, the other allowed data are those which characterize the name or type of the measured liquid without any ambiguity.

Except in the case of direct selling to the public it is allowed to replace the printing device under the following conditions:

- in case of conversion by a memory device, or
- when both parties have the possibility to be present to conclude the transaction, by any appropriate means to inform the two parties of the conditions of conversion.

The type approval certificate may indicate how to gain access to the memorized data.

[Section 3.7.5 was discussed at length in Paris. Consensus text for this section was, for the most part, the text in the 2CD.]

3.7.6 In addition to the quantity at metering conditions and the volume at base conditions or the mass, which shall be displayed according to 2.9.2, the values of other measured quantities (density, pressure, temperature) shall be accessible for testing purposes.

Scale intervals for indication of density, pressure and temperature shall be smaller than or equal to one fifth of the maximum permissible errors fixed in Table 4.2 of section 2.7.2.2 for associated measuring devices.

3.7.7 The temperature sensor shall respond rapidly to temperature changes in order to measure the temperature of the liquid going through the meter in a sufficiently accurate way.

[The addition of new section 3.7.7 is based on a comment from Belgium. Actual type approval requirements for this new section are found in Section 6.1.10.]

3.8 Calculator

All parameters necessary for the elaboration of indications that are subject to legal metrology control, such as unit price, calculation table, correction polynomial, etc. shall be present in the calculator at the beginning of the measurement operation.

The calculator may be provided with interfaces permitting the coupling of other devices. When these interfaces are used, the instrument shall continue to function correctly and its metrological functions shall not be influenced or affected.

4 Measuring systems equipped with electronic devices

4.1 General requirements

4.1.1 Electronic measuring systems shall be designed and manufactured such that their metrological functions are safeguarded and their errors do not exceed the maximum permissible errors as defined in 2.5 under rated operating conditions.

4.1.1.1 Interruptible electronic measuring systems shall be designed and manufactured such that, when they are exposed to the disturbances specified in Section A.11 of Annex A:
either a) significant faults do not occur;
or b) checking facilities detect and act upon, in accordance with 4.3, the significant faults or any incorrectness in the generation, transmission (taking into account 4.3.2.1), processing, or indication of the measurement data.

[Change to Section 4.1.1.1 (b) based on a comment from the Netherlands.]

4.1.1.2 Non-interruptible measuring systems shall be designed and manufactured in such a way that no significant faults occur when they are exposed to the disturbances specified in A.4.

4.1.2 It is the responsibility of the manufacturer to decide whether a given type of measuring system is interruptible or not, taking into account the applicable rules of security and type of application. However, measuring systems for direct selling to the public shall be interruptible.

When, at the time of type approval, it is not possible to specify the future utilization of the instrument, the requirements in 4.1.1.2 apply.

4.1.3 The requirements in 4.1.1 shall be met durably. For this purpose, electronic measuring systems shall be provided with the checking facilities specified in 4.3.

4.1.4 A type of a measuring system is presumed to comply with the requirements in 4.1.1 and 4.1.3 if it passes the inspection and tests specified in 6.1.11.1 and 6.1.11.2.

4.1.5 Measuring systems shall permit the retrieval of the measurement result just before a malfunction, in particular significant faults and/or power supply failure, occurred and was detected by the checking facilities.

4.2 Power supply device

4.2.1 When the flow is not interrupted during the failure of the principal power supply device, the measuring system shall be provided with a means to safeguard all measuring functions during that failure.

4.2.2 When the flow is interrupted during the failure of the principal power supply device, the provisions in 4.2.1 shall be met, or data contained at the moment of the failure shall be saved and shall be available for (on-demand) display on an indicating device subject to legal metrology control during a period of at least 15 minutes, to permit the conclusion of the current transaction.

4.2.2.1 If a provision for the manual activation of the display is present, the display shall be available for a minimum of two minutes.

4.2.2.2 As an alternative, except for direct selling to the public, the last transaction may be memorized and available for (on-demand) display upon the restoration of power.

[Text edits in Section 4.2.2 based on comment by South Africa.]

4.3 Checking facilities

4.3.1 Action of checking facilities

The detection by the checking facilities of incorrectnesses in the generation, transmission, processing and/or indication of measurement data shall result in the following actions, according to the type.

4.3.1.1 Checking facilities of type N: a visible or audible alarm for the attention of the operator.

4.3.1.2 Checking facilities of types I or P:

a) for non-interruptible measuring systems:

- automatic correction of the malfunction, or
 - stopping only the faulty device when the measuring system without that device continues to comply with the regulations, or
 - a visible or audible alarm for the operator; this alarm shall continue until the cause of the alarm is suppressed. In addition, when the measuring system transmits data to ancillary devices, the transmission shall be accompanied by a message indicating the presence of a malfunction.
- This bullet is not applicable for disturbances specified in A.11.

Where an instrument is equipped with facilities to estimate the quantity of liquid which has passed through the system during a malfunction, all indications of such values shall be clearly identified as estimates.

b) for interruptible measuring systems, in particular for fuel dispensers:

- automatic correction of the malfunction, or
- stopping only the faulty device, when the measuring system without that device continues to comply with the regulations, or
- stopping the flow.

4.3.2 Checking facilities for the measuring device

Checking facilities shall be designed and manufactured such that they can verify the presence of the measuring device, its correct operation, and the correctness of the data transmission.

4.3.2.1 When the signals generated by the measuring device are in the form of pulses, each pulse representing an elementary quantity, significant faults shall be detected by checking facilities and acted upon.

These checking facilities shall be of type P and the checking shall occur at time intervals not exceeding the duration of the measurement of an amount of liquid equal to the minimum specified quantity deviation.

While not a requirement for initial and subsequent verification, it shall be possible during type approval to ensure that these checking facilities function correctly:

- by disconnecting the transducer, or
- by interrupting one of the sensor's pulse generators, or
- by interrupting the electrical supply of the transducer.

4.3.2.2 For electromagnetic meters only, where the amplitude of the signals generated by the measuring device is proportional to the flowrate, the following procedure may be used:

A simulated signal with a shape similar to that of the measurement signal is fed into the input of the secondary device, representing a flowrate between the minimum and maximum flowrate of the meter. The checking facility shall check the primary and the secondary device. The equivalent digital value is checked to verify that it is within predetermined limits given by the manufacturer and consistent with the maximum permissible errors.

This checking facility shall be of type P or I. In the latter case, the checking shall occur at least every five minutes.

Note: Following this procedure, additional checking facilities (more than two electrodes, double signal transmission etc.) are not required.

4.3.2.3 For other technologies checking facilities providing equivalent levels of security remain to be developed.

4.3.3 Checking facilities for the calculator

These checking facilities shall verify that the calculator system functions correctly and ensure the validity of the calculations made.

There are no special means required for indicating that these checking facilities function correctly.

4.3.3.1 The checking of the functioning of the calculation system shall be of types P or I. In the latter case, the checking shall occur at least every five minutes, except in the case of fuel dispensers, for which it shall occur at each delivery. The objective of the checking is to verify that:

- the values of all permanently memorized instructions and data are correct, and (see Annex B – bullet 1)
- all procedures of internal transfer and storage of data relevant to the measurement result are performed correctly (see Annex B – bullet 2).

4.3.3.2 The checking of the validity of calculations shall be of type P. This consists of checking the correct value of all data related to the measurement whenever these data are internally stored or transmitted to an ancillary device through an interface. In addition, the calculation system shall be provided with a means of controlling the continuity of the calculation program (“watch-dog”).

4.3.4 Checking facility for the indicating device

This checking facility shall verify that the primary indications are displayed and that they correspond to the data provided by the calculator. In addition, the checking facility shall verify the presence of the indicating devices, if they are removable. These verifications may be performed in one of two possible ways; they may be performed either according to first possibility which is presented in Section 4.3.4.2 or they may be performed according to the second possibility which is presented in Section 4.3.4.3.

4.3.4.1 While not a requirement for initial and subsequent verification, it shall be possible during type approval to ensure that the checking facility of the indicating device is working properly.

4.3.4.2 The first possibility is to automatically control the complete indicating device. The checking facility of the indicating device is of type P. However, it may be of type I if a primary indication is provided by another device of the measuring system or if the indication may be easily determined from other primary indications (for example, in the case of a fuel dispenser, it is possible to determine the price to pay from the quantity and the unit price).

4.3.4.3 The second possibility is to automatically check the data transmitted to the indicating device and the electronic circuits used for the indicating device, except the driving circuits of the display itself, and to also check the display.

The automatic checking facility of the transmitted data and of the electronic circuits used for the indicating device is of type P. However, it may be of type I if a primary indication is provided by another device of the measuring system, or if the indication may be easily determined from other primary indications (for example, in the case of the presence of a price indicating device, it is possible to determine the price to pay from the quantity and the unit price).

The checking facility of the display shall provide the ability to visually check the entire display which shall meet the following description:

- a) for fuel dispensers:
 - displaying all the elements ("eights" test if appropriate),

- blanking all the elements ("blank" test), and displaying "zeros" for quantity and, if applicable, displaying the valid unit price and "zeros" for price, just before a new delivery starts.

Each step of the sequence shall last at least 0.5 second.

b) for all other interruptible and non-interruptible measuring systems, the test sequence shall be as described under (a) (above) or any other automatic test cycle which indicates all possible states for each element of the display.

This ability to visually check the display shall be of type I for fuel dispensers and of type N for other interruptible and non-interruptible measuring systems, but it is not mandatory for a malfunction to result in the actions described in 4.3.1.

4.3.5 Checking facilities for ancillary devices

An ancillary device (repeating device, printing device, self-service device, memory device, etc.) shall include a checking facility of type I or P. The object of this checking facility is to verify the presence of the ancillary device (when it is a necessary device) and to verify the correct transmission of data from the calculator to the ancillary device.

In particular, the checking of a printing device aims at ensuring that the data received and processed by the printing device correspond to the data transmitted by the calculator. At least the following shall be checked:

- presence of paper,
- transmission of data,
- the electronic control circuits (except the driving circuits of the printing mechanism itself).

While not a requirement for initial and subsequent verification, it shall be possible during type approval to ensure that the checking facility of the printing device is functioning by an action that forces a printing malfunction. This action should be a simulated incorrectness in the generation, transmission (taking into account 4.3.2.1), processing, or indication of measurement data.

Where the action of the checking facility is a warning, this warning shall be given on the ancillary device concerned or on another visible part of the measuring system.

[Changes in Section 4.3.5 are to remove the word "fault" from the text, and incorporate a UK comment.]

4.3.6 Checking facilities for the associated measuring devices

Associated measuring devices shall include a checking facility of type P. The aim of this checking facility is to ensure that the signal given by these associated devices is inside a pre-determined measuring range.

Data from associated measuring devices shall be read at least 5 times during a quantity equal to the minimum measured quantity. Each time the data is read there shall be a check.

5 Requirements specific to certain types of measuring systems

5.1 Fuel dispensers

Except where otherwise specified, the requirements in this section do not apply to LPG dispensers.

5.1.1 Where installed, the ratio between the maximum and the minimum flowrate may be smaller than 10 provided that it is not less than five. This (as-installed) requirement is different than the requirement of section 2.3.3.3.

5.1.2 When the measuring system includes its own pump, a gas elimination device shall be installed immediately upstream of the meter inlet.

5.1.3 When the measuring system is intended for installation in a centrally pumped system, or for a remote pump, the general provisions in 2.10 shall be applied.

If it is not intended to install a gas elimination device, there shall be no risk of air intake or gas release. In this case, an automatic facility (such as a storage tank level detector) shall automatically prevent further deliveries when the storage tank minimum level is reached (see also 2.10.2).

[Changes to Section 5.1.3 based upon comments from UK and Canada.]

5.1.4 Where a gas indicator is fitted, it shall not have a venting device as mentioned in 2.11.

5.1.5 Fuel dispensers shall be equipped with a device for resetting the quantity indicating device to zero.

If these systems also include a price indicating device, this indicating device shall be fitted with a zero setting device.

5.1.6 The minimum height for the figures of the resettable quantity indicator is 10 mm.
The minimum height for the resettable price indicator is 10 mm.
The minimum height for the unit price is 4 mm.

5.1.7 When only one nozzle can be used during a delivery, and after the nozzle has been replaced, the next delivery shall be inhibited until the indicating device has been reset to zero.

When two or more nozzles can be used simultaneously or alternately, and after the utilized nozzles have been replaced, the next delivery shall be inhibited until the indicating device has been reset to zero. Moreover, by design, the provisions in the first paragraph of 2.16.1 shall be fulfilled.

The above requirements do not apply when an auxiliary hand pump is used.

5.1.8 Measuring systems having a maximum flowrate not greater than 3.6 m³/h shall have a minimum measured quantity not exceeding 5 L.

5.1.9 When the measuring system is fitted with a ticket printing device which is subject to control, this printing device shall comply with the relevant requirements in 3.4. In addition, any printing operation shall prevent the continuation of the delivery until a reset to zero has been performed. However, the printing operation shall not change the quantity indicated on the indicating device.

5.1.10 Fuel dispensers shall be interruptible.

5.1.11 In addition to requirements in 4.2.2, electronic fuel dispensers shall be such that the minimum duration of operation of the display shall be either:

- at least 15 min continuously and automatically after the failure of the principal electrical supply, or
- a total of at least 5 min in one or several periods controlled manually during one hour after the failure.

The instrument shall be supplied with electric power for the 12 hours preceding a test of this requirement.

In addition, electronic fuel dispensers shall be designed so that an interrupted delivery cannot be continued after the power supply has been re-established if the power failure has lasted more than 15 seconds.

5.1.12 When several fuel dispensers have a common indicating device it shall be impossible to use any of these measuring systems simultaneously.

5.1.13 The checking of the operation of the calculator, as described in 4.3.3.1, shall be performed at least once for each delivery.

5.1.14 It is not required to display quantities, and prices if applicable, that correspond to a small number of “minimum increments of registration” at the beginning of the delivery. The display of quantity or price may start after the hidden quantity has been reached.

The quantity thus hidden shall not be greater than two times the minimum specified quantity deviation. The hidden price shall not be greater than the price corresponding to that quantity.

5.1.15 All dispensers with electronic indicators shall be fitted with a time-out device that terminates a transaction (i.e. the dispenser is reset to zero before delivery starts), should a period of inactivity (no flow) of more than 120 seconds occur during the transaction.

5.2 Measuring systems on road tankers

5.2.1 The provisions hereafter apply to measuring systems mounted on road tankers or on transportable tanks for the transport and delivery of liquids of low viscosity (≤ 20 mPa.s) and stored at atmospheric pressure, with the exception of foaming potable liquids (see Section 5.6 for these requirements).

5.2.2 Tanks equipped with measuring systems may comprise one or more compartments.

5.2.3 The compartments of road tankers shall be fitted with an anti-swirl device, except when the measuring system is fitted with a gas separator which complies with 2.10.8.

5.2.4 When a tank comprises more than one compartment, each compartment shall be provided with an individual (manual or automatic) closing device in each outlet line.

5.2.5 In conformity with national regulations on their use, each measuring system shall be allocated to a specific product or to a range of products for which the meter has been approved.

The pipework shall, to the extent possible, be designed so that products cannot become mixed in the measuring system.

5.2.6 Subject to the requirements in 2.16.2, a measuring system mounted on a road tanker may include empty or full hoses or both.

5.2.7 The quantity indicating device shall include a zero setting device complying with 3.2.4.

When the measuring system is fitted with a ticket printing device, any printing operation shall prevent the continuation of the delivery until a reset to zero has been performed..

5.2.8 Measuring systems mounted on road tankers may be designed to operate by pump only, or by gravity only, or with the choice of either pump or gravity, or by gas pressure.

5.2.8.1 Measuring systems fed by pump only may operate either empty hose or full hose and shall comply with the following requirements 5.2.8.1.1 and 5.2.8.1.2.

5.2.8.1.1 As there is a risk that the requirements in 2.10.2 related to the absence of air or gas cannot be met, the measuring system shall have a suitable gas elimination device upstream of the meter. (See sections 2.10.7, 2.10.8, and 2.10.9.)

5.2.8.1.2 When, in a measuring system, the pressure at the outlet of the meter can be lower than atmospheric pressure, but still higher than the saturated vapour pressure, an automatic means to prevent any air from entering the meter shall be installed.

When the pressure at the outlet of the meter cannot be lower than atmospheric pressure (this is especially the case for systems operating solely full hose), the use of automatic devices for slowing down and stopping the flow is not required.

5.2.8.2 Measuring systems operating solely by gravity shall comply with the following requirements.

5.2.8.2.1 The equipment shall be so constructed that the total contents of the compartment(s) can be measured at a flowrate greater than or equal to the minimum flowrate of the measuring system.

5.2.8.2.2 If there are connections with the gas phase in the tank of the road tanker, appropriate devices shall prevent any gas from entering the meter.

5.2.8.2.3 The requirements in 2.10.3 concerning non-pumped flow shall apply.

A pump downstream of the transfer point for increasing the flowrate may be authorized if the foregoing provisions are complied with. This pump shall not cause a fall in pressure in the meter.

5.2.8.2.4 Where an air release to atmosphere is required to ensure the complete emptying of all piping downstream of the transfer point, it shall be automatic in operation.. Means for visual or automatic detection of the complete emptying are mandatory in this case.

5.2.8.3 Measuring systems capable of being operated either by gravity or by pump shall comply with the requirements in 5.2.8.1 and 5.2.8.2.

5.2.8.4 Measuring systems operated by means of gas pressure may operate empty hose or full hose. The pipework which links the meter to the device intended to prevent any gas from entering the meter as specified in point 2.10.3 shall have no constriction or component likely to cause a pressure loss which could generate gas pockets by releasing the gas dissolved in the liquid.

These systems shall include a pressure gauge which indicates the pressure in the tank. The dial of this gauge shall indicate the range of permissible pressures.

5.3 Measuring systems for the unloading of ships' tanks and of rail and road tankers using an intermediate tank

5.3.1 Measuring systems designed to measure quantities of liquids during the unloading of ships' tanks and of rail and road tankers may include an intermediate tank in which the liquid level determines the transfer point. This intermediate tank may be designed to ensure the elimination of gas.

The cross section of the intermediate tank shall be such that a quantity equal to the minimum specified quantity deviation corresponds to a difference in level of at least 2 mm.

5.3.2 In the case of road and rail tankers, the intermediate tank shall automatically ensure a constant level, visible or detectable, at the beginning and at the end of the measurement operation. The level is considered to be constant when it settles within a range corresponding to a quantity of no more than the minimum specified quantity deviation.

5.3.3 In the case of ships' tanks, it is not necessary to provide for the automatic maintenance of a constant level. Where such a provision is not made, it shall be possible to measure the contents in the intermediate tank.

If the ships' tank is unloaded by means of pumps located in the bottom of the ship, the intermediate tank may be used only at the beginning and at the end of the measurement operation.

5.4 Measuring systems for liquefied gases under pressure (other than LPG dispensers)

5.4.1 Only full hose measuring systems are authorized (unless section 5.4.9 is applicable).

5.4.2 The design of the measuring system shall ensure that the product in the meter remains in a liquid state during the measurement. (See also Annex B.)

5.4.3 A thermometer well shall be provided close to the meter for verification purposes.

5.4.4 Provisions shall be made for fitting a pressure measuring device downstream and close to the meter. This measuring device shall be available for verification. If necessary, provisions for sealing shall be made.

5.4.5 When the quantity is measured using a system mounted on a road tanker, any connection between the gaseous phases of the vehicle's tank and of the receiving tank is prohibited.

For other measuring systems for liquefied gas, such connections are permitted when the quantities of gas transferred via these connections are measured by means of suitable measuring instruments and subtracted from the delivered quantity.

5.4.6 Safety valves may be incorporated in measuring systems in order to prevent abnormally high pressures. If they are located downstream of the meter, they shall open to the atmosphere or be connected to the receiving tank.

In no case shall the safety valves located upstream of the meter be connected to the valves located downstream by pipes which bypass the meter.

5.4.7 When the conditions of operation require the use of detachable hoses, these hoses shall remain full if their quantities are greater than the minimum specified quantity deviation.

Detachable full hoses shall be fitted with special connections for full hoses, so-called couplers or self-sealing valves. Manually operated blow-off devices shall be provided at the ends of these hoses, if necessary.

5.4.8 For measuring systems mounted on road tankers the quantity indicating device and its printing device, if provided, shall comply with the requirements in 5.2.7.

5.4.9 The provisions in 5.4 also apply for measuring systems for liquefied carbon dioxide with the following exceptions:

- only empty hose measuring systems are authorized (see 5.4.1),
- the connection between the gaseous phases of the vehicle's tank and of the receiving tank is permitted if (i) a device is installed to allow compensation of the delivered quantity by an amount relating to the quantity of vapour returned in the gas line, or (ii) compensation is made by automatic calculation. However, in both cases, flow from the delivery tank to the receiving tank by means of the gas return line shall be securely prevented,
- the requirements of 5.4.7 are not mandatory for these systems.

5.5 Fuel dispensers for liquefied gases under pressure (LPG dispensers)

[Changes in Section 5.5 respond to 5 different international comments.]

5.5.1 Requirements in 5.1.1, 5.1.5, 5.1.6, 5.1.8 to 5.1.15, 5.4.1, and 5.4.2 are applicable to LPG dispensers for motor vehicles. The ratio between the maximum flowrate and the minimum flowrate may be smaller than five provided that it is not less than 2.5.

5.5.2 Provisions shall be made to ensure that the LPG in the measuring system remains in the liquid state. This is usually accomplished through a pressure-maintaining device.

5.5.3 A thermometer well may be provided close to the meter. When it is not provided, the legal metrology authority may require that the manufacturer or the owner of the measuring system provide an equivalent means for measuring temperature.

When a pressure-maintaining device is used, provision shall be made for fitting a pressure-measuring device close to the meter and upstream of the pressure-maintaining device. This measuring device shall be available for verification. If necessary, provision for sealing shall be made.

5.5.4 Connection between the gas phase of the feed tank and the gas phase of the vehicle's tank, a vapor return line, is prohibited.

5.5.5 When only one nozzle can be used during a delivery, and after the nozzle has been replaced, the next delivery shall be inhibited until the indicating device has been reset to zero.

When two or more nozzles can be used simultaneously or alternately, and after the utilized nozzles have been replaced, the next delivery shall be inhibited until the indicating device has been reset to zero. Moreover, by design, the provisions in the first paragraph of 2.16.1 shall be fulfilled.

Moreover, in both cases, when the flow is stopped by emergency means and a predetermined delay is exceeded, the current delivery shall be stopped and the next delivery shall be preceded by a reset to zero.

5.5.6 A non-return valve, downstream of the meter, is mandatory. The pressure loss caused by it shall be sufficiently low to be considered negligible.

5.5.7 Hoses shall be fitted with special connections for full hoses, so-called couplers or self-sealing valves.

5.5.8 Safety features shall not affect the metrological performance.

5.5.9 When the measuring system is provided with a conversion device, it shall be possible to verify separately the indications of quantity at measuring conditions and associated measuring devices.

5.5.10 The construction of the nozzle shall be such that, at the moment of coupling or uncoupling, the loss of liquid does not exceed the minimum specified quantity deviation.

5.6 Measuring systems for milk, beer, and other foaming potable liquids

5.6.1 The following requirements apply to transportable measuring systems for foaming potable liquids which are mounted on road tankers and also to fixed measuring systems used for the reception or delivery of these liquids.

5.6.2 The transfer point in reception installations is defined by a constant level air elimination system upstream of the meter. The air elimination device must make use of a constant level tank which is usually combined in one device but may be separate if the air elimination device is downstream of the constant level tank and before the meter. It must be possible to verify a constant level in the air elimination device before and after each measurement. The level shall be established automatically.

5.6.2.1 The air elimination device may be placed either upstream of the pump or between the pump and the meter.

The air elimination device is necessary whether the meter is fed by gravity, by emptying milk churns, by means of an auxiliary pump, or by means of a vacuum system.

If the milk is introduced by means of a pump or a vacuum system, a gas elimination device is necessary. This device may be combined with the constant level tank.

5.6.2.2 The requirement of section 2.13.3 does not apply to measuring systems for milk, and the meter may be fed by means of a vacuum system. In this case, the pressure inside the pipe work connecting the constant level tank to the meter will be lower than atmospheric pressure and the tightness of the joints of this connection must be particularly well ensured. It must be possible to check the tightness and a notice plate drawing attention to this checking shall be provided.

5.6.2.3 In all installations for reception, the pipe work upstream of the air elimination device shall empty completely and automatically under the rated operating conditions.

5.6.2.4 The constant level in the air elimination device/constant level tank is monitored by means of a sight glass or a level indicating device. The level is considered to be constant when it settles within a range defined by two marks at least 15 mm apart and corresponding to a difference in quantity of no more than twice the minimum specified quantity deviation.

5.6.2.5 If, in order to meet the above condition, devices for reducing the flowrate are incorporated in the measuring system, the flowrate during the period of reduced flowrate shall be at least equal to the minimum flowrate of the meter.

5.6.2.6 If, in a reception installation, the measured liquid flows to a level lower than that of the meter, a device shall automatically ensure that the pressure at the outlet of the meter remains above atmospheric pressure.

5.6.2.7 Measuring systems shall be fully filled before a measurement commences. In the case of receiving systems, if it is not practical to fill the measuring system before a measurement, it is acceptable to determine the quantity required to fill the measuring system and this quantity shall be indicated on the data plate of the measuring system so that it can be taken into account, by calculation, in the first measurement of a reception period. The first quantity measured by the measuring system during a reception period shall be equal to or greater than the quantity which is necessary for the complete filling of the measuring system.

5.6.3 In spite of the general requirements of section 2.10 concerning the elimination of air or gases, the gas elimination devices shall meet the requirements of section 2.10.1 under operating conditions only, such as when air enters at the beginning and end of each measuring operation.

However, when the measuring system is equipped with hoses, which are designed to be coupled to the outlet of the supply tank, the gas elimination device shall also comply with the requirements in 2.10.1 during the whole measuring operation.

For reception equipment, the user shall be able to ascertain the leak-tightness of the connections so that no air may enter upstream of the meter during measuring. For delivery equipment, the system shall be assembled so that the liquid pressure in the connecting pipes running from the supply tank is always positive

5.6.4 The indicating device of a transportable measuring system and its printing device, if provided, shall comply with the requirements in 5.2.7.

5.7 Measuring systems on pipelines and systems for loading ships

5.7.1 The ratio between the maximum flowrate and the minimum flowrate of the measuring system may be less than 5 (see Section 2.3.3). In this case, the measuring system shall be fitted with an automatic checking device to verify that the flowrate of the liquid to be measured is within the restricted measuring range of the measuring system.

[Change to Section 5.7.1 based on a comment by South Africa.]

This checking device shall be of type P and shall meet the requirements in 4.3.1.2.

The maximum and minimum flowrates may be determined in relation to the liquid to be measured and manually introduced into the calculator.

5.7.2 Prevention of gas flow

The measuring system shall be provided with a means of eliminating any air or gas contained in the liquid unless the entry of air into the liquid or release of gas from the liquid is prevented by the configuration of the pipe work or by the arrangement and operation of the pump(s).

5.7.3 Special conditions of installation

Reverse flow of the liquid to be measured in the measuring system shall be prevented by a suitable device, unless otherwise approved.

5.7.4 Sampling device

The measuring system may include a sampling device intended to determine the properties of the liquid to be measured.

It is not necessary to take into account the quantity of the sample in the results of the measurement if this sample is less than 0.1 times the maximum permissible error of the measuring system.

5.8 Measuring systems intended for the refuelling of aircraft

The requirements of this section also apply to the refuelling of helicopters.

5.8.1 General

5.8.1.1 Measuring systems intended for refuelling aircraft are full hose measuring systems.

5.8.1.2 The gas elimination device function may be performed by a microfilter water elimination device provided that provisions in 2.10 are fulfilled.

A water elimination device may be placed downstream of the meter. The water draw-off valve should not to be sealed.

5.8.1.3 These systems shall be interruptible measuring systems.

5.8.2 Stationary measuring systems

5.8.2.1 The requirements applicable to fuel dispensers apply to stationary measuring systems intended for the refuelling of aircraft, except those in 5.1.1.

5.8.2.2 These systems may include their own pumps or be designed for installation in a centrally pumped system.

5.8.2.3 The microfilter-water elimination device shall be fitted upstream of the gas elimination device.

5.8.3 Mobile measuring systems

5.8.3.1 General

5.8.3.1.1 If more than one transfer point is provided, interlocks should prevent the usage of two or more together unless the arrangement is such that it would be difficult to use them on different aircrafts at the same time.

5.8.3.1.2 They may be designed for defuelling aircraft provided that the connecting point for defuelling is located upstream of the gas elimination device. A weir-type sight glass is not mandatory.

Interlocks may also be necessary to prevent bypassing metered liquid through the return line back to the supply tank while delivering fuel to the aircraft.

5.8.3.1.3 Where the microfilter-water elimination device may be used to perform the function of the gas elimination device, it may be verified by an examination of documents only if provisions in 2.10 are fulfilled.

5.8.3.1.4 Each installation shall be provided with or accompanied by:

- instructions for use,
- a liquid circulation plan,
- a description of necessary operations for use,
- a description of control and connecting devices positions related to their use.

5.8.3.2 Aircraft refuelling tanker measuring systems

The requirements in 5.2.2, 5.2.3, 5.2.4, 5.2.6, 5.2.7 and 5.2.8.1 apply.

Note: For good practice in the use of the system, when the aircraft refuelling tanker measuring system is fitted with a device used to perform the gas extractor or special gas extractor function, a manometer should be provided upstream of the pump in order to detect depressions when they occur. Its indications should be easily visible by the operator.

5.8.3.3 Aircraft hydrant measuring systems

5.8.3.3.1 The gas elimination device may be a device performing the function of a gas extractor when the underground pipe:

- is designed for easy elimination of the air contained in the pipe with appropriate devices,
- is fitted with special connecting devices for full hoses,
- is supplied so that, in designed supply conditions, no gaseous formation can occur or enter the underground pipe.

5.8.3.3.2 When the aircraft hydrant measuring system is equipped with a device for froth recovery and reinjection, it shall be located upstream of the gas elimination device and it shall not permit permanent introduction of gas into the meter.

5.8.3.3.3 Depressurization valves for the hoses so that connection and disconnection can be easily made, shall be accompanied with interlocks to prevent metered liquid from being diverted.

5.9 Blend dispensers

5.9.1 The requirements in Sections 5.1.1 to 5.1.15 are applicable to both parts of the multigrade-dispenser and to the gasoline part of the gasoline-oil-dispenser (with the text “blend dispensers” in the place of “fuel dispensers” where appropriate). However, by design, the ratio between the maximum flowrate and the minimum flowrate may be at least five in the case of multigrade-dispensers.

5.9.2 When only one nozzle can be used during a delivery, and after the nozzle has been replaced, the next delivery shall be inhibited until the indicating device has been reset to zero.

When two or more nozzles can be used simultaneously or alternately, and when the utilized nozzles have been replaced, the next delivery shall be inhibited until the indicating device has been reset to zero. Moreover, by design, the provisions in the first paragraph of 2.16.1 shall be fulfilled.

5.9.3 The requirements in 5.9.4 through 5.9.8 do not apply if the designations of the various mixtures do not allow conclusions to be drawn concerning the ratio of quantities of the two components.

Examples for such designations:

- number of stars (2, 3, 4 stars),
- octane-number (92, 95, 98 octane),
- two-stroke-mixture (without designation such as 5 %).

Moreover, the requirement in 5.9.4 or 5.9.5 only applies where the measuring system provides the indication of the mixed quantity and the price of the mixture depends on the blending ratio. It does not apply where the measuring system provides:

- an indication of the mixed quantity and the price does not depend on the blending ratio, or,
- a quantity indication for each component of the mixture and does not provide an indication of the mixed quantity.

To permit compliance with the requirement in 5.9.4 or 5.9.5 to be verified, it is necessary:

- for multigrade-dispensers to measure the quantities of both components,
- for gasoline-oil-dispensers to measure either the quantities of oil and gasoline or the quantities of oil and mixture,

- for both types to make the separate collection of both components feasible during verification.

5.9.4 The accuracy of the blending ratio for multigrade-dispensers shall be as follows.

The designations of the various mixtures being indicated as the ratio of quantities of the two components (for example 1:1), the real ratio of the quantities of two components shall be within the limits of $\pm 5\%$, i.e. the real ratio $k_{\text{real}} = V_2/V_1$ of quantities of both components determined during the verification shall be equal to the nominal (indicated) ratio k_{nom} , within the limits:

$$k_{\text{min}} = k_{\text{nom}} - 0.05 k_{\text{nom}} \quad \text{and} \quad k_{\text{max}} = k_{\text{nom}} + 0.05 k_{\text{nom}}$$

Examples:

Designation	3:1	1:1	1:3
k_{nom}	0.333	1.00	3.00
k_{min}	0.316	0.95	2.85
k_{max}	0.350	1.05	3.15

5.9.5 The accuracy of the blending ratio for gasoline-oil-dispensers shall be as follows.

If V_1 is the quantity of the minority component in the mixture and V_2 the quantity of the majority component, the real quantity ratio related to the minority component, expressed as a percentage $[T = 100 \times V_1 / (V_1 + V_2)]$, shall be equal to the nominal ratio within a limit of plus or minus:

- 5% in relative value, or
- 0.2% absolute, whichever is greater.

In other words, T being the real quantity ratio as a percentage, and T_{nom} the nominal quantity ratio as a percentage, the following must be satisfied:

$$[T - T_{\text{nom}}] / T_{\text{nom}} \leq 0.05$$

if the nominal quantity ratio is at least 4 %, and

$$[T - T_{\text{nom}}] \leq 0.2 \%$$

if the nominal quantity ratio is less than 4 %.

5.9.6 If the blend dispenser is capable of delivering more than one mixture with the same nozzle and the blending ratios are being guaranteed, the installation of two hoses and a special blending device close to the transfer point is required.

If the blend dispenser can deliver only one mixture per nozzle, the blending device may be installed inside the dispenser, using a single hose per nozzle.

5.9.7 If the blend dispenser is capable of delivering one or both single components (in addition to the mixtures) with a common nozzle, a device shall prevent the liquid flow through the unused part of the blend device.

5.9.8 The lubricating oil part of a gasoline-oil-dispenser shall be designed so as to prevent air bubbles in the oil passing through the oil measuring device. There shall also be a device to detect the presence of oil. In the absence of oil, delivery has to be stopped by means, e.g. of:

- an intermediate oil reservoir and a device which stops the delivery when the oil reservoir is empty,
- a pressure detecting device which stops the delivery in the case of an oil pressure drop.

5.10 Self-service arrangement with fuel dispensers

The following requirements apply to measuring systems covered by 5.1, 5.5, or 5.9 when fitted with self-service arrangements.

It is advisable, in particular, that national or international regulations include provisions prescribing that primary indications shall remain accessible to the parties involved in the transaction up to the settlement of the transaction.

5.10.1 General requirements

5.10.1.1 Marking, sealing and connection of the components are left to national regulations.

5.10.1.2 Where the self-service device serves two or more dispensers, each dispenser shall be provided with a dispenser identification number that shall accompany any primary indication provided by the self-service device.

5.10.1.3 The primary indications on indicating devices and printing devices of the self-service arrangement shall not indicate any mutual differences.

Scale intervals of the primary indication on indicating devices and the printing devices and memory devices of the self-service arrangement shall be the same.

However, in case the data transmission between the fuel dispenser and self-service device is in the form of pulses, all primary indications provided by the self-service device shall not indicate any mutual differences for any measured quantity relating to the same measurement. The indications provided by the self-service device shall not deviate from (each of) the primary indications on the fuel dispenser by more than one scale interval or the greater of the two scale intervals if they differ.

5.10.1.4 Printing devices on the self-service arrangement shall not reproduce the indications of a dispenser as the difference between two printed values.

5.10.1.5 Indication of information that is not subject to metrological control is allowed, provided that it cannot be confused with metrological information.

5.10.1.6 A change of the type of payment and/or mode of operation shall not be effective before the end of the current measurement operation.

5.10.1.7 The self-service arrangement, including provisions related to clearly defined methods of operation, shall be such that at least one primary indication for the benefit of the customer must be available at least up to the settlement of the transaction to enable the delivered quantity and the price to pay to be checked.

5.10.1.8 In the case of a self-service arrangement that totalizes the delivered quantities for different registered customers over the course of time, the minimum measured quantity is not affected by the scale interval used for such totalizations.

5.10.2 Attended service mode

If the dispenser indicating device provides the only primary indication, shall bear a legend, which is clearly visible to the customer which states that the next authorization of a particular dispenser can only be given by the supplier after settlement of the current transaction and that in case of dispute, the primary indication on the indicating device of the fuel dispenser is correct.

Notes:

1. In attended service mode, the settlement of the transaction takes place before the customer leaves the site of the delivery.
2. In attended service mode, the measurement operation ends at the moment settlement of the transaction takes place.

5.10.2.1 Attended post-payment (See also Annex B.)

- 5.10.2.1.1 Where the self-service arrangement includes a device that provides an additional primary indication (additional to those of the indicating device of the dispenser), it shall consist of at least one installation for the reproduction of the quantity and the price (if calculated) indicated by the primary dispenser indicating device, consisting of at least:
- an indicating device for the benefit of the supplier , and
 - a display, or a printing device for the issue of a receipt, for the benefit of the customer.

5.10.2.1.2 For self-service devices with temporary storage (temporary storage mode) of measurement data of dispensers the following requirements apply:

- a) temporary storage of measurement data shall be restricted to one delivery for each dispenser, that is, a dispenser may be authorized for a next delivery before the previous transaction on the same dispenser has been settled;
- b) the mandatory primary indication for the benefit of the supplier shall be accompanied by a clear mark representing the sequence (for example, the numbers 1 or 2, or the letters A or B); and
- c) when a mandatory primary indication of the self-service device is out of service, the self-service arrangement may continue its operation provided that it no longer uses any temporary storage, and that the dispenser indicating device remains the primary indication. In such a case, the fuel dispensers shall bear a legend, which is clearly visible to the customer, which states that in case of dispute, the primary indication on the indication device of the fuel dispenser is correct.

5.10.2.1.3 Where the mandatory primary indication for the benefit of the customer is provided by a device in the form of a separate constructional unit and this unit becomes uncoupled, or if the checking facilities detect a malfunction, the temporary storage mode shall be prohibited and the dispenser indicating device remains the primary indication.

5.10.2.1.4 The self-service device should be capable of indicating the status of the dispensers (e.g. running, authorized, or unauthorized) that are connected to the self-service device and in the case of multiple modes of service and/or type of payment, also that particular status of the measuring system.

5.10.2.2 Pre-payment in attended service mode

5.10.2.2.1 The requirements of 3.6 are applicable.

5.10.2.2.2 A printed or hand-written receipt of the pre-paid amount shall be provided.

5.10.3 Unattended service mode

5.10.3.1 General

In unattended service mode, the end of the measurement operation is the end of the registration (printing and/or memorizing) of information concerning the measurement operation.

5.10.3.1.1 The self-service arrangement shall provide additional primary indications by means of:

- a printing device for the issue of a receipt to the customer, and
- a device (printing or memory device) on which measurement data are registered for the benefit of the supplier.

5.10.3.1.2 When the printing devices or a memory device, as required by 5.10.3.1.1, are not able to provide any indication or become unserviceable, the customer shall be clearly warned by automatic means before the operation commences.

Passing from attended to unattended service mode shall not be possible before correct operation of the arrangement is concluded as feasible by the checking facilities, including compliance with the above provision.

Memorized data older than 3 months may be automatically deleted

5.10.3.1.3 Where the self-service arrangement is provided with individual volume totalizers, one for each registered customer and visible to the customer, the provisions of 5.10.3.1.1 and 5.10.3.1.2 do not apply.

5.10.3.1.4 Self-service devices shall be provided with a means for controlling the continuity of the calculation program (“watch-dog”) for ensuring the discontinuation of the current delivery when the continuity of the processor program is no longer ensured.

The next effective acceptance of notes, cards or other equivalent mode of payment shall only take place if the continuity of the processor program is re-established.

5.10.3.1.5 When a power supply failure occurs, the delivery data shall be memorized. The requirements of 5.1.9 apply.

5.10.3.2 Delayed-payment

The printed and/or memorized indications as mentioned in 5.10.3.1 shall contain sufficient information for further checking and at least, the measured quantity, the price to pay (if calculated) and information to identify the particular transaction (e.g. the dispenser number, location, date, time).

5.10.3.3 Pre-payment in unattended service mode

5.10.3.3.1 Following the termination of each delivery, the printed and/or memorized indications as intended in 5.10.3.1 shall be made available, clearly indicating the amount which has been pre-paid and the price corresponding to the liquid obtained.

These printed and/or memorized indications may be divided into two parts as follows:

- a) one part provided prior to the delivery on which the pre-paid amount is shown and recognizable as such,
- b) one part provided following the termination of delivery, provided that it is clear from the information provided on both parts that they are related to the same delivery.

5.10.3.3.2 The requirements of 3.6 are applicable.

5.11 Other self-service arrangements

It is advisable, in particular, that national or international regulations include provisions prescribing that primary indications shall remain accessible to the parties interested in a transaction up to the settlement of this transaction.

Measuring systems, especially those for loading road or rail tankers, may be designed in such a way that the transaction is not settled when the customer leaves the loading site, in implicit agreement with the supplier.

In this case, national or international regulations may prescribe that the self-service arrangement provide additional primary indications by means of:

- a printing device for the issue of a receipt to the customer, and
- a device (printing or memory device) on which measurement data are registered for the benefit of the supplier.

The printed and/or memorized indications shall contain sufficient information for further checking and at least the measured quantity and information to identify the particular transaction (e.g. the system number, location, date, time).

Moreover, after a delivery, measuring systems shall not be capable of being reset to zero and authorized until measurement data are memorized or printed out.

5.12 Unattended delivery

Measuring systems for unattended delivery (such as those for fuel delivery from road tankers into filling stations or for direct sale to the public) may be designed in such a way that the transaction is not settled when the supplier leaves the delivery location. This arrangement is only applicable when there is an existing agreement between the parties.

National or regional regulations may require that measuring systems intended for unattended delivery are equipped with:

- an automatic device to identify the unloading location;
- a printing device for automatically issuing a receipt to the customer; and
- a memory device in which the following data are recorded: identification of the measuring system, measurement data, time and date of delivery, and the unloading location.

[New section 5.12 based on a proposal from France (LNE).]

6 Metrological control

[The testing requirements of this section moved to Annex A, Section A.2.]

6.1 Type approval

6.1.1 General

Measuring systems subject to legal metrology control shall be subject to type approval.

In addition, the constituent elements of a measuring system, mainly those listed below, and the sub-systems which include several of these elements, are subject to separate type approval upon the request of the manufacturer:

- measuring device,
- electronic calculator,
- indicating device,
- meter,
- gas separator,
- gas extractor,
- special gas extractor,
- conversion device,
- ancillary devices providing or memorizing measurements results,
- meter sensor,
- temperature sensor,
- pressure sensor,
- density sensor.

Note: In some countries, the expression "type approval" can be reserved for complete measuring systems. In this case, it is advisable that types of constituent elements be submitted to a procedure similar to type approval, making it possible to certify the conformity of the type of a constituent element to the regulation.

The constituent elements of a measuring system shall comply with the relevant requirements even when they have not been subject to separate type approval (except, of course, in the case of ancillary devices and additional devices that are exempted from the controls).

Unless otherwise specified in this Recommendation, a measuring system shall fulfil the requirements without adjustment of the system or of its elements during the course of the tests. Relevant tests belonging together should be carried out on the same measuring system or element, under the same conditions and without adjustment. If, however, an adjustment has been performed or tests have been conducted with another measuring system and/or device this shall be documented and justified in the test report.

6.1.2 Documentation

6.1.2.1 The application for type approval of a measuring system or of a constituent element of a measuring system shall include the following documents:

- a description giving the technical characteristics and the principle of operation,
- a drawing or photograph,
- a list of the components with a description of their constituent materials when this has a metrological influence,
- an assembly drawing with identification of different components,
- for measuring systems, the references of the approval certificates of the constituent elements, if any,
- for measuring systems and meters fitted with correction devices, a description of how the correction parameters are determined,
- a drawing showing the location of seals and verification marks,
- a drawing of regulatory markings.
- Test data showing compliance with requirements [not mandatory]
- Installation practices or operational constraints [including characteristics of acceptable liquids]
- Instructions on how to access metrological software [and revision number of software]

6.1.2.2 In addition, the application for type approval of an electronic measuring system shall include:

- a functional description of the various electronic devices;
- a flow diagram of the logic, showing the functions of the electronic devices;
- any document or evidence which shows that the design and construction of the electronic measuring system comply with the requirements of this Recommendation, in particular section 4.3.;
- manufacturer's desired test severity levels for temperature, humidity, and mechanical tests (see Section A.10.2, A.10.3, and A.10.4); and
- manufacturer's desired test severity level for electrical disturbance tests (see Section A.11).

6.1.2.3 The applicant shall provide the body responsible for the evaluation with an instrument representative of the final type.

Other specimens of the type may be considered necessary by the body responsible for the type evaluation to estimate the reproducibility of the measurements (see 6.1.5.2.4).

6.1.3 Type approval certificate

The following information shall appear on the type approval certificate:

- name and address of the recipient of the approval certificate,
- name and address of the manufacturer, if it is not the recipient,
- type and/or commercial designation,
- rated operating conditions,
- other principal metrological and technical characteristics, if required ,
- type approval mark,
- period of validity,
- information on the location of marks for type approval, initial verification and sealing (e.g. picture or drawing),
- list of documents accompanying the type approval certificate,
- specific remarks,
- the version of the metrological part of the evaluated software, if applicable, and
- sufficient information to perform the tests during initial and subsequent verification

6.1.4 Modification of an approved type

6.1.4.1 The recipient of the type approval shall inform the body responsible for the approval of any modification or addition which concerns an approved type.

6.1.4.2 Modifications and additions shall be subject to a supplementary type approval when they influence, or are likely to influence, the measurement results or the instrument's regulatory conditions of use.

The body having approved the initial type shall decide to which extent the examinations and tests described below shall be carried out on the modified type in relation with the nature of the modification.

6.1.4.3 When the body having approved the initial type judges that the modifications or additions are not likely to influence the measurement results, this body allows the modified instruments to be presented for initial verification without granting a supplementary type approval.

A new or supplementary type approval must be issued whenever the modified type no longer fulfils the provisions of the initial type approval.

6.1.5 Type approval of a meter, a measuring device, or a meter sensor

A type approval may be given for a complete meter; it may also be given:

- for the measuring device (as defined in T.1.3) when this is intended to be connected to different types of calculators, and
- for the meter sensor (as defined in T.1.3.1), only when the transducer (T.1.3.2) is a separate device and the sensor is intended to be connected to different types of transducers.

Examinations and tests shall be carried out on the meter alone, on the meter sensor, or on the measuring device when it is the subject of a separate application for type approval.

Required testing is specified in Annex A.

[General testing requirements are now in Annex A, Section A.1]

[Accuracy test requirements are now in Annex A, Section A.6]

[Endurance test requirements are now in Annex A, Section A.7]

[Section 6.1.5.2.4 moved into Section 6.2.1 on initial verification.]

6.1.6 Type approval of a gas elimination device

As a rule, tests shall be carried out to prove that the air or gas eliminating devices satisfy the requirements in 2.10.8 or 2.10.9.

It is acceptable, however, that tests are not carried out at flowrates greater than 100 m³/h and that the air separating devices are approved by analogy with devices of the same design with smaller dimensions.

6.1.7 Type approval of an electronic calculator, including the indicating device.

When an electronic calculator is submitted to separate type approval, type approval tests are conducted on the calculator alone, simulating different inputs with appropriate standards.

[Accuracy tests on an electronic calculator are now in Annex A, Section A.8]

6.1.8 Type approval of a conversion device

There are two approaches to verify a conversion device complies with the requirements of Section 2.7. The first approach verifies the conversion device as part of a complete measuring system. The second approach allows for the verification of a conversion device, or its separate components, other than as part of a complete measuring system.

Accuracy tests on conversion devices are found in Annex A, Section A.9.

[Changes to Section 6.1.8 (now Section A.9 in Annex A) are based on comments from France and an extensive re-write of Section 2.7.]

6.1.9 Type approval of an ancillary device

6.1.9.1 When an ancillary device that provides primary indications is intended to be approved separately, its indications shall be compared with those provided by an indicating device that has already been approved and which has the same scale interval, or a smaller one.

The results shall satisfy the provisions in 2.9.5 and 5.10.1.3.

As far as possible, the necessary conditions for compatibility with other devices of a measuring system are stated in the type approval certificate.

6.1.9.2 Electronic devices may be approved separately when they are used for the transmission of primary indications or other information necessary for their determination, e.g. a device which concentrates information from two or more calculators and transmits it to a single printing device.

When at least one of the signals of this information is analog, the device shall be tested in association with another device whose maximum permissible errors are provided by this Recommendation.

When all the signals of this information are digital, the above provision may be applied; however, when the inputs and outputs of the device are available, the device can be tested separately, in which case it shall introduce no error; only errors due to the testing method may be found out.

In both cases and as far as possible, the necessary conditions for compatibility with other devices of a measuring system are stated in the type approval certificate.

6.1.10 Type approval of a measuring system

The type approval of a measuring system consists of verifying that the measuring system (with constituent elements that have not been subject to separate type approvals) satisfies all applicable system requirements, and that the constituent elements are compatible with one another.

Tests for carrying out the type approval of a measuring system shall therefore be determined on the basis of the type approvals already granted for the constituent elements of the system.

When none of the constituent elements has been subject to separate type approval, all of the applicable tests of Annex A shall be performed on the measuring system. However, when the relevant constituent elements of the measuring system are all approved separately, it is possible to satisfy type approval requirements based on examination of the applicable type approval certificates and an assessment of element compatibility.

It is also appropriate to reduce the type evaluation program when the measuring system includes constituent elements identical to those which equip another measuring system that has already been approved, and when the operating conditions of these elements are identical.

Notes:

1. It is advisable that constituent elements be subject to separate type approval when they are intended to equip several types of measuring systems. This is particularly advisable when the various measuring systems have different manufacturers and when the bodies in charge of type approval are different.
2. If an applicant for a measuring system like to use constituent elements already tested for other applicants the test results for these elements may only be used with written permission of the applicant for the constituent element concerned.
3. Section 3.7.7 requires that the measuring system temperature sensor shall respond rapidly to temperature changes in the liquid. This requirement is considered to be met when the sensor is able to respond to at least 90% of the variation in the temperature of the liquid within a 15 second time period when the measuring system is operating at its highest flow rate.

[Changes to Section 6.1.10 based on comments from the Netherlands. Note 3 added based on a comment from Belgium.]

6.1.11 Type approval of an electronic device

In addition to the examinations or tests described in the preceding paragraphs, an electronic measuring system or an electronic constituent element of this system shall be subject to the following tests and examinations.

6.1.11.1 Design inspection

This examination of documents aims at verifying that the design of electronic devices and their checking facilities comply with the provisions of this Recommendation, clause 4 in particular.

It includes:

- a) an examination of the mode of construction and of the electronic sub-systems and components used, to verify their appropriateness for their intended use,
- b) consideration of **malfunctions** likely to occur, to verify that in all considered cases these devices comply with the provisions of 4.3,
- c) verification of the presence and effectiveness of the test device(s) for the checking facilities.

6.1.11.2 Performance tests

These tests aim at verifying that the measuring system complies with the provisions of 4.1.1 with regard to influence quantities. These tests are specified in Annex A.

- a) Performance under the effect of influence factors:

When subjected to the effect of influence factors as provided for in Annex A, the equipment shall continue to operate correctly and the errors shall not exceed the applicable maximum permissible errors.

- b) Performance under the effect of disturbances:

When subjected to external disturbances as provided for in Annex A, the equipment shall either continue to operate correctly or detect and indicate the presence of any significant faults. Significant faults shall not occur on non-interruptible measuring systems.

6.1.11.3 Equipment under test (EUT)

Tests are carried out either on the complete measuring system or on the constituent elements.

The EUT shall be included in a set-up representative of the normal operation of the measuring system. In particular, the calculator with indication device shall be installed in its final housing; or, in the case of a fuel dispenser, shall be installed in a housing representative of the final housing. The type approval body may decide that a type approval certificate covering a given type of calculator with indicating device will cover any other housing for the same type.

In all cases, ancillary devices may be tested separately.

6.2 Initial verification

6.2.1 General

Initial verification of a measuring system may be carried out in one or more stages.

When one or more stages precede the definitive initial verification of the complete measuring system, the results of the tests in the preceding stages shall be taken into account during the final stage.

Whatever are the number and location of the stages and whatever are the test means, it must be possible to conclude that the measuring system, installed at the site of use, fulfils all applicable requirements under rated operating conditions.

When, as part of an initial verification, verification of the meter is planned to be carried out with a liquid which differs from the liquid the meter is intended to measure, comparative tests with these two liquids shall also be carried out to determine the maximum permissible errors on this verification. It may be necessary to have several specimens of the type available. Applicable information shall be stated in the type approval certificate.

[This paragraph moved from Section 6.1.5.2]

6.2.2 Tests

6.2.2.1 The initial verification of the measuring system shall include:

- an examination for conformity of the measuring system and its constituents with the respective types;
- a metrological examination of the measuring system; if possible, this examination is carried out within the limits of operating conditions for the system;
- an operational test of the gas elimination device, if possible and if there is one, with no need to verify that the maximum errors applicable to this device (specified in Section 2.10) are met;
- for measuring systems on road tankers, the gas elimination device shall be tested for the removal of air pockets by emptying the supply tank (compartment) during a delivery (product depletion test) (see also Annex B);
- when necessary, a test of the variations of the internal volume of the hoses in full hose measuring systems, e.g. in the case of a hose reel;
- an operational test of the control valve preventing the emptying of the hose during non-operating periods, for full hose measuring systems; and
- a determination of the residual quantities in empty hose measuring systems (see Section 2.14).

6.2.2.2 When initial verification takes place in more than one stage, test results obtained from the preceding stages shall be taken into account during the initial verification of the complete measuring system.

6.2.2.3 A measuring system shall be designed so as to allow its verification under conditions of use. If necessary, special devices shall be provided.

The measuring systems shall be constructed so that a standard of appropriate size can be fitted for testing the meters. When a test can only be carried out with the pumps running, which normally does not allow for testing with the meter stopped at the start and at the end of the test, the standard shall be suitable for continuous operation (for example, quantity standard with a flow diverting mechanism, pipe prover, weighing instrument, etc.).

6.2.2.4 In special cases, documented in the type approval certificate, the principle of 6.2.2.3 may be waived provided that:

- the meters are verified on a control test station with liquids having the same characteristics as those to be measured at the place of installation. The verification is carried out on the measuring device only, but includes the required straight pipes upstream and downstream of the meter (see 3.1.6.2 to 3.1.6.4 or 3.1.7.1 or 3.1.8.1 or 3.1.9.1) associated with a compatible and equivalent indicating device, provided that all the elements having a direct mechanical link with the measuring device and being able to influence the measurement are verified at the same time;
- the meters continue to have all required periodic calibrations, controlled and fixed by the metrology service.

To complete the verification, the measuring systems concerned shall be subjected to a qualitative check of function and installation.

6.2.2.5 It shall be possible to carry out metrological testing of the associated measuring devices and sensors that are constituent elements of the measuring system under actual operating conditions. Verification of these devices should fulfil the requirements of Sections 2.7.

[Changes to Section 6.2.2.3 (and the addition of Sections 6.2.2.4 and 6.2.2.5) are based on suggested edits from Belgium and the Netherlands.]

6.3 Subsequent verification

Subsequent verification and its requirements are the responsibility of the national authorities.

[Section 6.3 has been returned to the 1CD version which is less prescriptive.]

ANNEX A

TYPE APPROVAL PERFORMANCE TESTS

(Mandatory)

[Annex A has been heavily re-written in the DR to accomplish the following:]

- *Moved parts of R117-1 that are really "testing requirements" out of Section 6 and inserting them into Annex A (this should make it much easier to strip R117-1 of test methods/requirements in the creation of R117-2 "Test Methods")*
- *Updated all of the ISO & IEC references and test requirements in the testing sections.]*

A.1. General

Annex A (this annex) defines the program of performance tests intended to verify that the measuring system or its constituent elements operate as intended in a specified environment and under specified conditions. Each test indicates, where appropriate, the reference conditions for determining the intrinsic error.

Different kinds of tests are specified:

- Accuracy tests (including repeatability and flow disturbances tests, if applicable),
- Influence factor tests, and
- Electronic disturbance tests.

The tests specified in this Recommendation constitute minimum test procedures. Further tests may be undertaken, if necessary, to ensure compliance of the measuring system or its constituent elements with the requirements of this document.

When the effect of one influence quantity is being evaluated, all other influence quantities are to be held relatively constant, at values close to reference conditions.

Newer versions of the specific IEC and ISO standards referenced in this annex's performance tests may be used so long as the metrological authority confirms that the newer version continues to agree with the testing required by this document.

[from Section 6.1.5.1 in the 2CD of R117-1]

Tests are normally carried out on the complete meter, fitted with an indicating device, with all the ancillary devices, and with the correction device, if any. However, the meter subject to testing need not be fitted with its ancillary devices when the latter are not likely to influence the accuracy of the meter and when they have been verified separately (for example, an electronic printing device). The measuring device may also be tested alone provided that the calculator and the indicating

device have been verified. The meter sensor may be tested alone provided that the transducer and the calculator with indicating device have been verified.

If this measuring device or meter sensor is intended to be connected to a calculator fitted with a correction device, the correction algorithm as described by the manufacturer must be applied to the output signal of the transducer to determine its errors.

A.2. Uncertainties of Measurement

[from Section 6 in the 2CD of R117-1]

When a test is conducted, the expanded uncertainty of the determination of errors on indications of volume or mass shall be less than one-fifth of the maximum permissible error applicable for that test on type approval and one-third of the maximum permissible error applicable for that test on other verifications. The estimation of expanded uncertainty is made according to the “Guide to the expression of uncertainty in measurement” (1995 edition) with $k = 2$.

A.3. Reference conditions

Ambient temperature :	15 °C to 35 °C
Relative humidity :	25 % to 75 %
Atmospheric pressure :	84 kPa to 106 kPa
Power voltage :	Nominal voltage (V_{nom})
Power frequency :	Nominal frequency (F_{nom})

During each test, the temperature shall not vary by more than 5 °C and the relative humidity shall not vary by more than 10 % within the reference range.

A.4. Test volumes

Some influence quantities should have a constant effect on measurement results and not a proportional effect related to the measured volume. If the value of the significant fault is related to the measured volume, (in order to be able to compare results obtained in different laboratories) it is necessary to perform a test on a fixed volume and flow rate, and not less than the minimum measured quantity. Furthermore, the test volume shall be in accordance with the uncertainty requirements mentioned in A.2.

A.5. Influence of the liquid temperature

Temperature tests concern the ambient temperature and not the temperature of the liquid used. It is therefore advisable to use a simulation test method such o that the temperature of the liquid does not influence the test results.

A.6. Accuracy tests on a meter, a measuring device, or a meter sensor

[from Section 6.1.5.2 in the 2CD of R117-1]

A.6.1. The errors of the meter shall be determined at a minimum of six flowrates which are distributed over the measuring range at regular intervals. The highest flowrate shall be between $0.8 \times Q_{\text{max}}$ and Q_{max} . At each flowrate, the errors shall be determined at least three times, independently. Each error shall not be greater than the maximum permissible error (in absolute

value). In addition, for quantities equal to or greater than five times the minimum measured quantity, the repeatability requirement in 3.1.2.2 applies.

A.6.2 Tests shall be carried out to ensure that the errors of indication on the meter will not exceed the maximum permissible errors at the limits of each of the rated operating conditions. The type approval body is required to determine and document the operating conditions at which the type approval testing will be conducted (some guidance for this is provided in Annex B of this document).

[Changes to this section based on input from France and the Netherlands.]

A.6.3 In addition to the tests defined in A.6.1, the error shall be determined at the minimum measured quantity.

A.6.4 If appropriate, flow disturbances may be carried out. For tests with flow disturbances, the applicable maximum permissible errors are those fixed in line A of Table 2 for the measuring system. (See also Annex B.)

A.7. Endurance tests on a meter, a measuring device, or a meter sensor

[from Section 6.1.5.3 of the 2CD of R117-1]

A.7.1. Endurance tests should be carried out at the maximum flowrate of the meter using the liquid the meter is intended to measure or a liquid with similar characteristics.

A.7.2. When the meter is intended to measure different liquids, the test should be carried out with the liquid that provides the most severe conditions. The liquid(s) used for testing shall be fully documented.

A.7.3. The duration of the endurance test shall be 100 hours in one or several periods. The endurance test shall be carried out at a flowrate between $0.8 \times Q_{\max}$ and $Q_{\max}$. (An accuracy test as defined in A.6.1 shall precede the endurance tests.)

A.7.4. It is preferred that the meter is subjected to the endurance test on a test bench. However, it is accepted that the meter be temporarily mounted in a measuring system in normal operation; in this case, it is required that the nominal operating flowrate of the measuring system is more than $0.8 \times Q_{\max}$.

A.7.5. After the endurance test, the meter is again subject to a new accuracy test according to A.6.1. The deviations between the errors determined before and after the endurance test shall remain within the limits specified in 3.1.2.3 without any changes of the adjustment or corrections.

A.8. Accuracy tests on a electronic calculator

[from Section 6.1.7 of the 2CD of R117-1]

A.8.1. Accuracy tests include an accuracy test on the indications of measurement results (volume at metering conditions or price to pay). For this purpose, the error obtained on the indication of the result is calculated considering the true value is the one calculated taking into account the value of the simulated quantities applied to inputs of the calculator and using standard methods for calculation. The maximum permissible errors are those fixed in Section 2.8.

A.8.2. When the calculator carries out calculations for a conversion device, tests specified in Section A.8.1 are performed for the calculation of volume at base conditions or mass. The maximum permissible errors are those fixed in 2.7.2.1.2.

A.8.3. Accuracy tests also include an accuracy test on the measurement of each characteristic quantity of the liquid. For this purpose, the error obtained on the indication of each of these characteristic quantities (these indications are mandatory considering 3.7.7) is calculated by considering the true value as that provided by the standard connected to the inputs of the calculator and which simulates the corresponding associated measuring device. For the indication of each of these quantities, the maximum permissible errors fixed in 2.7.2.1.1 shall be applied.

A.8.4. It is then necessary to perform a test to check the presence and operation of checking facilities relevant to associated measuring devices mentioned in 4.3.6.

A.9. Accuracy tests on conversion devices

[from Section 6.1.8 of the 2CD of R117-1]

As described in Section 2.7, there are two approaches to verify a conversion device. The approach to be applied shall be specified by the applicant for type approval.

A.9.1. First approach: Verification of the conversion device as part of a complete measuring system. It is necessary to verify whether the conversion device connected to all its associated measuring devices complies with provisions in 2.7.1. For that purpose, the quantity at metering conditions which is converted is assumed to be without any error. The maximum permissible errors are those fixed in 2.7.1.2. The “true” values for the characteristic quantities shall be derived from appropriate standards (thermostatically controlled bath, liquids with standard density, pressure balance, etc). The quantity at metering conditions may be simulated.

A.9.2. Second approach: Verification of a conversion device or its separate components (other than as part of a complete measuring device).

In case of the second approach, it is necessary to verify separately:

- the calculator with its indicating device, to verify that the provisions in 2.7.2.1, A.8.2, A.8.3 and A.8.4 are fulfilled;
- the associated measuring devices, by using the indication of the characteristic quantities on the accompanying calculator with indicating device, to verify that the provisions in 2.7.2.2 are fulfilled; and
- the associated measuring sensors to verify that the provisions in 2.7.2.2 are fulfilled.

The “true” values for the characteristic quantities shall be derived from appropriate standards (thermostatically controlled bath, liquids with standard density, pressure balance, etc).

The necessary conditions for compatibility shall be stated in the type approval certificate.

A.10. Influence factors tests on electronic devices

A.10.1. General

A.10.1.1. The general reference for testing requirements in Annex A, Section A.10, is OIML D-11: 2004.

A.10.1.2. For each performance test, typical test conditions are indicated; these conditions correspond to the climatic, and mechanical environment conditions to which measuring systems are usually exposed.

A.10.1.3. The applicant for type approval may indicate special/specific environmental conditions in the documentation supplied to the metrology service, based on the intended use of the instrument. In this case, the metrology service shall conduct performance tests at severity levels corresponding to these environmental conditions. If type approval is granted, the data plate shall indicate the corresponding limits of use. Manufacturers shall inform potential users of the conditions of use for which the instrument is approved. The metrology service shall verify that the conditions of use are met.

A.10.2. Severity levels for temperature

The thermal conditions in which measuring systems and ancillary devices are used vary considerably. They are not only highly dependent of the place on earth, ranging from arctic to tropical regions, but are also considerably dependent on indoor or outdoor applications. Devices being typically used indoors in one country can be typically used outdoors in other countries. Therefore, no classes combining low and high temperature limits have been described in this Recommendation.

In general, the choice of the lower and the upper temperature limits should preferably left to national (or regional) legislation, taking into account the severity levels in A.10.5 and A.10.6.

A.10.3. Severity levels for humidity

The following table gives a classification for the severity levels for the humidity tests

Class	Severity level Damp heat (cyclic)	Description
H1	-	This class applies to enclosed locations. Humidity is not controlled. Humidification is used to maintain the required conditions, where necessary. Measuring instruments are not subject to condensed water, precipitation, or ice formations. The conditions of this class may be found in continuously manned offices, certain workshops, and other rooms for special applications.
H2	1	This class applies to enclosed locations whose humidity is not controlled. Measuring instruments may be subject to condensed water, water from sources other than rain, and to ice formations. The conditions of this class may be found in some entrances and staircases of buildings, in garages, cellars, certain workshops, factory buildings and industrial process plants, ordinary storage rooms for frost-resistant products, farm buildings, etc.
H3	2	This class applies to open locations with average climatic conditions, thus excluding polar and desert environments.

A.10.4. Severity levels for mechanical tests

The following table gives a classification for the severity levels for mechanical tests:

Class	Severity level Vibration	Description
M1	-	This class applies to locations with vibration and shocks of low significance • for instruments fastened to light supporting structures subject to negligible vibrations and shocks (transmitted from local blasting or pile-driving activities, slamming doors, etc.)
M2	1	This class applies to locations with significant or high levels of vibration and shock • vibration and shock transmitted from machines and passing vehicles in the vicinity or adjacent to heavy machines, conveyor belts, etc.
M3	2	This class applies to locations where the level of vibration and shock is high and very high • for instruments mounted directly on machines, conveyor belts etc.

A.10.5. Dry heat

Test method:	Dry heat (non condensing)
Object of the test:	To verify compliance with the provisions in 4.1.1 under conditions of high temperature.
References:	IEC 60068-2-2 (1974-01), with amendments 1 (1993-02) and 2 (1994-05), Environmental testing , Part 2: Tests, Test B: Dry heat. IEC 60068-3-1 (1974-01) + Supplement 1 (1978-01), Environmental testing, Part 3: Background information, section 1: Cold and dry heat tests.
Test procedure in brief (*):	The test consists of exposure of the EUT to the specified high temperature under "free air" conditions for a 2-hour period after the EUT has reached temperature stability. The change of temperature shall not exceed 1 °C/min during heating up and cooling down. The absolute humidity of the test atmosphere shall not exceed 20 g/m³. When testing is performed at temperatures lower than 35 °C, the relative humidity shall not exceed 50 %. The EUT shall be tested at the reference temperature of 20 °C after 1 hour conditioning, • at the specified high temperature, 2 hours after temperature stabilization, • after 1 hour recovery of the EUT at the reference temperature of 20 °C. During tests, the EUT shall be in operation. Simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

Test severities:	One of the following severity levels shall be specified:					
	1	2	3	4	5	unit
	30	40	55	70	85	°C

Maximum allowable variations:	All functions shall operate as designed. All errors shall be within the maximum permissible errors.
-------------------------------	--

(*) This test procedure has been given in condensed form, for information only, and is adapted from the referenced IEC-publication. Before conducting the test, the applicable publication should be consulted. This comment also applies to the test procedures hereafter.

A.10.6. Cold

Test method: Cold

Object of the test: To verify compliance with the provisions in 4.1.1 under conditions of low temperature.

References: IEC 60068-2-1 (1990-05) with amendments 1 (1993-02) and 2 (1994-06) Environmental testing, Part 2: Tests, test A: Cold.
IEC 60068-3-1 (1974-01) + Supplement 1 (1978-01),
Environmental testing, Part 3: Background information, Section 1: Cold and dry heat tests.

Test procedure in brief: The test consists of exposure of EUT to the specified low temperature under "free air" conditions for a 2-hour period after the EUT has reached temperature stability. The EUT shall be tested:

- at the reference temperature of 20 °C after 1 hour conditioning,
- at the specified low temperature, 2 hours after temperature stabilization,
- after 1 hour recovery of the EUT at the reference temperature of 20 °C.

During tests, the EUT shall be in operation, simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

Test severities:	One of the following severity levels shall be specified				
	1	2	3	4	unit
	5	- 10	- 25	- 40	°C

Maximum allowable variations:

- All functions shall operate as designed.
- All errors shall be within the maximum permissible errors.

A.10.7. Damp heat, cyclic (condensing)

Test method: Damp heat, cyclic (condensing)

Object of the test: To verify compliance with the provisions in 4.1.1 under conditions of high humidity when combined with cyclic temperature changes.

- This test is applicable only for outdoor equipment.

References: IEC 60068-2-30 (2005-08) Environmental testing Part 2: Tests, Test Db and guidance: Damp heat, cyclic (12 + 12-hour cycle).
IEC 60068-3-4 (2001-08) Environmental testing - Part 3-4: Supporting documentation and guidance - Damp heat tests..

Test procedure in brief: The test consists of exposure of the EUT to cyclic temperature variations between, 25 °C and the appropriate upper temperature, maintaining the relative humidity above 95 % during the temperature changes and during the phases at low temperature, and at 93 % at the upper temperature phases. Condensation should occur on the EUT during the temperature rise.

A 24 h cycle consists of:

- temperature rise during 3 h
- temperature maintained at upper value until 12 h from the start of the cycle
- temperature lowered to lower value within 3 h to 6 h, the rate of fall during the first hour and a half being such that the lower value would be reached in 3 h
- temperature maintained at lower value until the 24 h cycle is completed.

The stabilizing period before and recovery after the cyclic exposure shall be such that all parts of the EUT are approximately at their final temperature.

The power supply is not on when the influence factor is applied.

After the application of the influence factor and recovery the EUT shall be tested at a minimum of one flow rate. During tests, the EUT shall be in operation, simulated inputs are permitted.

Test severities:	One of the following severity levels shall be specified:		Unit
Severity levels	1	2	
Upper temperature	40	55	°C
Duration	2	2	cycles

Maximum allowable variations: After the application of the influence factor and recovery:

- all functions shall operate as designed, and
- all errors shall be within the maximum permissible errors.

A.10.8. Vibration (random)

Test method: Random vibration

Object of the test: To verify compliance with the provisions in 4.1.1 under conditions of random vibration.

References: IEC 60068-2-47 (2005-04) Environmental testing Part 2-47: Test methods. Mounting of components, equipment and other articles for vibration, impact and similar dynamic tests.

IEC 60068-2-64 (1993-05), with correction 1 (1993-10)
Environmental testing- Part 2: Test methods, test Fh: Vibration, broadband random (digital control) and guidance.

Test procedure in brief: The EUT shall, in turn, be tested in three, mutually perpendicular axes, mounted on a rigid fixture by its normal mounting means.

The EUT shall normally be mounted so that the gravitational force acts in the same direction as it would in normal use.

The power supply is not on when the influence factor is applied. After the application of the influence factor, the EUT shall be tested at a minimum of one flow rate.

Test severities:	The following severity level shall be specified:	
	2	
Total frequency range	10 -150 Hz	
Total RMS level	7 m.s ⁻²	
ASD level 10 –20 Hz	1 m ² .s ⁻³	
ASD level 20 –150 Hz	- 3 dB/octave	
Number of axes	3	
Duration per axis	2 minutes	

Maximum allowable variations:

After the application of the influence factor :

- all functions shall operate as designed and
- all errors shall be within the maximum permissible errors.

A.11. Electrical disturbances tests

A.11.1. General

The general reference for testing requirements in Annex A, Section A.11 is OIML D-11: 2004.

A.11.1.1. Severity levels for electrical disturbance tests

The following table gives a classification for electrical disturbance tests:

Class	Description
E1	This class applies to instruments used in locations with electromagnetic disturbances corresponding to those likely to be found in residential, commercial and light industrial environments (<i>as described in IEC EN 61000-6-1 which provides the criteria for this IEC testing</i>).
E2	This class applies to instruments used in locations with electromagnetic disturbances corresponding to those likely to be found in heavy industrial environments (<i>as described in IEC EN 61000-6-2 which provides the criteria for this IEC testing</i>).

The relation between the class and the applicable severity levels is given in the following table.

Severity level for class		Test	
E1	E2	Section	Description
1	1	A.11.2.1	AC mains voltage variation
NA	NA	A.11.2.2	DC mains voltage variation
2	3	A.11.3	AC mains power – voltage dips, short interruptions, and voltage variations
2	3	A.11.4	Bursts (transients) on AC and DC mains
3	3	A.11.5	Electrostatic discharge (ESD)
2	3	A.11.6	Fast transients/bursts on signal, data and control lines
2	2	A.11.7	Surges on signal, data and control lines
NA	1	A.11.8	DC mains power – voltage dips, short interruptions and voltage variations
NA	1	A.11.9	Ripple on DC input power ports
3	3	A.11.10	Surges on AC and DC mains lines
2	3	A.11.11.1	Radiated radio frequency electromagnetic fields of general origin
3	3	A.11.11.2	Radiated radio frequency electromagnetic fields (digital radio telephones)
2	3	A.11.11.3	Conducted disturbances, induced by radio-frequency fields

A.11.1.2. Electronic devices powered by batteries

There is a distinction between the tests for instruments powered by:

- (a) Disposable batteries,
- (b) General rechargeable batteries, and
- (c) Batteries of road vehicles.

For the case of disposable and rechargeable batteries of a general nature, no applicable standards are available.

Devices powered by non-rechargeable batteries or by rechargeable batteries that cannot be (re)charged during the operation of the measuring system, shall comply with the following requirements:

- (a) The device provided with new or fully charged batteries of the specified type shall comply with the applicable metrological requirements;
- (b) As soon as the battery voltage has dropped to a value specified by the manufacturer as the minimum value of voltage where the device complies with metrological requirements, this shall be detected and acted upon by the device in accordance with section 4.2.

For these devices, no special tests for disturbances associated with the "mains" power have to be carried out.

Devices powered by rechargeable auxiliary batteries that are intended be (re)charged during the operation of the measuring instrument shall both:

- (a) comply with the requirements for devices powered by non-rechargeable batteries or by rechargeable batteries that cannot be (re)charged during the operation of the measuring system, with the mains power switched off; and
- (b) comply with the requirements for AC mains powered devices with the mains power switched on.

Devices powered by the mains power and provided with a back-up battery for data-storage only, shall comply with the requirements for AC mains powered devices.

For electronic devices powered by the on-board battery of a road vehicle, a series of special tests for disturbances associated with the power supply are given in Section A.12 of Annex A (this Annex).

A.11.2. Mains voltage variations

A.11.2.1. AC mains voltage variation

Test method:	Variation in AC. mains power voltage (single phase)	
Object of the test:	To verify compliance with the provisions in 4.1.1 under conditions of varying AC mains power voltage.	
References:	IEC/TR3 61000-2-1 (1990-05) Electromagnetic compatibility (EMC), Part 2: Environment Section 1: Description of the environment – Electromagnetic environment for low-frequency conducted disturbances and signalling in public power supply systems. IEC 61000-4-1(2006-10) Basic EMC Publication, Electromagnetic compatibility (EMC), Part 4: Testing and measurement techniques, Section 1: Overview of IEC 61000-4 series	
Test procedure in brief:	The test consists of exposure of the EUT to the specified power condition while the EUT is operating under normal atmospheric conditions. During tests, the EUT shall be in operation, simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.	
Test severities	The following severity level shall be specified	
Severity level	1	
	Lower limit	Upper limit
Mains voltage: 1), 2)	$U_{\text{nom}} - 15\%$	$U_{\text{nom}} + 10\%$
Notes:	1) This test is not applicable to equipment powered by a road vehicle battery. 2) In the case of three phase power supply, the voltage variation shall apply for each phase successively. 3) The values of U are those marked on the measuring instrument. In case a range is specified, the “-” relates to the lowest value and the “+” to the highest value of the range.	
Maximum allowable variations:	All functions shall operate as designed. All errors shall be within the maximum permissible errors.	

A.11.2.2. DC mains voltage variation

Test method:	Variation in DC mains voltage
Object of the test:	To verify compliance with the provisions in 4.1.1 under conditions of varying DC mains voltage.
References:	IEC 60654-2 (1979-01), with amendment 1 (1992-09) Operating conditions for industrial-process measurement and control equipment. Part 2: Power Consolidated edition.
Test procedure in brief:	The test consists of exposure of the EUT to the specified power supply conditions while the EUT is operating under normal atmospheric conditions. During tests, the EUT shall be in operation, simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.
Test severity:	The DC operating range as specified by the manufacturer but not less than $U_{\text{nom}} - 15\% \leq U_{\text{nom}} \leq U_{\text{nom}} + 10\%$
Notes:	1) This test is not applicable to equipment powered by a road vehicle battery.
Maximum allowable variations:	At supply voltage levels between upper and lower limit: All functions shall operate as designed. All errors shall be within the maximum permissible errors.

A.11.3. AC mains voltage dips, short interruptions and voltage variations

Test method: Short time reductions in mains voltage

Object of the test: To verify compliance with the provisions in 4.1.1 under conditions of short time mains voltage reductions.

References: IEC 61000-4-11 (2004-03) Electromagnetic compatibility (EMC) - Part 4-11: Testing and Measuring techniques – Voltage dips, short interruptions and voltage variations immunity tests.
IEC 61000-6-1 (2005-03) Electromagnetic compatibility (EMC) - Part 6-1: Generic Standards – Immunity for residential, commercial and light-industrial environments (Severity Level 2)
IEC 61000-6-2 (2005-01) Electromagnetic compatibility (EMC) - Part 6-2: Generic standards – Immunity for industrial environments (Severity Level 3)

Test procedure in brief: A test generator suitable to reduce for a defined period of time the amplitude of the AC mains voltage is used
The performance of the test generator shall be verified before connecting the EUT.
The mains voltage reductions shall be repeated ten times with an interval of at least ten seconds.
The interruptions and reductions are repeated throughout the time necessary to perform the whole test; for this reason, more than ten interruptions and reductions may be necessary.
During tests, the EUT shall be in operation, simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

Test severities:		One of the following severity levels shall be specified								
Severity levels ⁽¹⁾		2			3					
Test		Test a	Test b	Test c	Test a	Test b	Test c	Test d	Test e	unit
Voltage reduction	Reduction (Dips)	0	0	70	0	0	40	70	80	%
	Duration **	0.5	1	25/30	0.5	1	10/12	25/30	250/300	cycles
Voltage inter- ruption	Interruption	> 95								%
	Duration	250								cycles
Notes		1) This test is not applicable to equipment powered by a road vehicle battery. 2) ** These duration values are for 50 Hz / 60 Hz, respectively.								

Maximum allowable variations:

- a) for interruptible measuring systems, either significant faults do not occur or checking facilities detect a malfunctioning and act upon in it accordance with 4.3 when significant faults occur
- b) for non-interruptible measuring systems, no significant faults occur.

A.11.4. Bursts (transients) on AC and DC mains

Test method:	Electrical bursts
Object of the test:	To verify compliance with the provisions in 4.1.1 under conditions where electrical bursts are superimposed on the mains voltage and, if applicable, on input/output and communication ports. • (This test is not applicable to instruments connected to road vehicle batteries; see section A.12 for specific testing requirements on these instruments.)
References:	IEC 61000-6-1 (2005-03) Electromagnetic compatibility (EMC) - Part 6-1: Generic Standards – Immunity for residential, commercial and light-industrial environments (Severity Level 2) IEC 61000-6-2 (2005-01) Electromagnetic compatibility (EMC) - Part 6-2: Generic standards – Immunity for industrial environments (Severity Level 3) IEC 61000-4-1 Electromagnetic compatibility (EMC) (2006-10), Part 4: Testing and measurement techniques, Section 1: Overview of IEC 61000-4 series IEC 61000-4-4 (2004-07) with correction (2006-08) Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 4: Electrical fast transient/burst immunity test. Basic EMC Publication.
Test procedure in brief:	A burst generator shall be used with the performance characteristics as specified in the referred standard. The test consists of exposure of the EUT to bursts of voltage spikes for which the repetition frequency of the impulses and peak values of the output voltage on 50 Ω and 1000 Ω load are defined in the referenced standard. The characteristics of the generator shall be verified before connecting the EUT. At least 10 positive and negative randomly phased bursts shall be applied. The injection network on the mains shall contain blocking filters to prevent the burst energy from being dissipated in the mains. The bursts are applied during all the time necessary to perform the test; therefore, more bursts than indicated above may be necessary. During tests, the EUT shall be in operation (simulated inputs are permitted). Tests shall be performed at a minimum of one flow rate.

Test severities:		One of the following severity levels shall be specified:		unit
Severity levels		2	3	
Amplitude (peak value)	Supply lines	1	2	kV
	Signal lines	0.5	1	kV
Notes		1) Tests on supply lines apply only for instruments powered by AC or DC mains power supply. 2) Tests on signal lines are applicable only for I/O signal, data and control ports with a cable length exceeding 3 meters (as specified by the manufacturer).		

Maximum allowable variations:

- a) for interruptible measuring systems
either significant faults do not occur or checking facilities detect a malfunctioning and act upon in it accordance with 4.3 when significant faults occur.
- b) for non-interruptible measuring systems,
no significant faults occur.

A.11.5. Electrostatic discharge

Test method:	Electrostatic discharge (ESD)
Object of the test:	To verify compliance with the provisions in 4.1.1 under conditions of direct and indirect electrostatic discharges.
References:	IEC 61000-6-1 (2005-03) Generic Standards Immunity for residential, commercial and light-industrial environments. IEC 61000-6-2 (2005-01) Generic Standards Immunity for industrial environments. IEC 61000-4-2 (2001-04) Electromagnetic compatibility (EMC) Part 4: Testing and measurement techniques, Section 2: Electrostatic discharge immunity test.
Test procedure in brief:	An ESD generator shall be used with a performance as defined in the referenced standards. The EUT shall be tested under reference conditions. For EUT not equipped with a ground terminal, the EUT shall be fully discharged between discharges. Contact discharge is the preferred test method. Air discharges shall only be used where contact discharge test cannot be applied. Direct application (Contact Discharge): The contact discharge mode is to be carried out on conductive surfaces, the electrode shall be in contact with the EUT. At least 10 discharges shall be applied to each test point, The time interval between successive discharges shall be at least 10 seconds, during the same measurement or simulated measurement. The discharges are applied during all the time necessary to perform the test; to that purpose more discharges than indicated above may be necessary. Indirect application (Air Discharge): The air discharges are applied in the contact mode to coupling planes mounted in the vicinity of the EUT. At least 10 discharges shall be applied to each test point, to the horizontal coupling plane, and to each position of the vertical coupling plane. The time interval between successive discharges shall be at least 10 seconds, during the same measurement or simulated measurement. The discharges are applied during all the time necessary to perform the test; to that purpose more discharges than indicated above may be necessary.

During tests, the EUT shall be in operation, simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

		The following severity level shall be specified:	unit
Severity level:		3	
Test voltage	Contact discharge	6	kV
	Air discharge	8	kV
Notes			

Maximum allowable variations:

- a) for interruptible measuring systems
either significant faults do not occur or checking facilities detect a malfunctioning and act upon in it accordance with 4.3 when significant faults occur
- b) for non-interruptible measuring systems,
no significant faults occur.

A.11.6. Fast transients / bursts on signal, data and control lines

Test method	Electrical fast transients/bursts
Object of the test	To verify compliance with the provisions in 4.1.1 under conditions where electrical bursts are superimposed on input/output and communication ports.
References	IEC 61000-6-1 (2005-03) Generic Standards Immunity for residential, commercial and light-industrial environments (Severity Level 2) IEC 61000-6-2 (2005-01) Generic Standards Immunity for industrial environments (Severity Level 3) IEC 61000-4-1 (2006-10) Basis EMC Publication; Electromagnetic compatibility (EMC); Part 4: Testing and measurement techniques; Section 1: Overview of IEC 61000-4 series. IEC 61000-4-4 (2004-07) with (2006-08) correction Electromagnetic compatibility (EMC) – Part 4: Testing and Measurement techniques – Section 4: Electrical fast transient/burst immunity test. Basic EMC Publication.
Test procedure in brief	A burst generator shall be used with the performance characteristics as specified in the referred standard. The test consist of exposure to bursts of voltage spikes for which the repetition frequency of the impulses and peak values of the output voltage on 50 Ω and 1000 Ω load are defined in the referred standard. The characteristics of the generator shall be verified before connecting the EUT. Both positive and negative polarity of the bursts shall be applied. The duration of the test shall not be less than 1 min for each amplitude and polarity. For the coupling of the bursts into the input/output and communication lines, a capacitive coupling clamp as defined in the standard shall be used. The bursts are applied during all the time necessary to perform the test; to that purpose more bursts than indicated above may be necessary. During tests, the EUT shall be in operation, simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

Test severities	One of the following severity levels shall be specified:		unit
Severity levels	2	3	
Amplitude (peak value)	0.5	1	kV
Notes:	1) Tests on signal lines are applicable only for I/O signal, data and control ports, with a cable length exceeding 3 meters (as specified by the manufacturer). 2) This test is not applicable to equipment powered by a road vehicle battery.		

Maximum allowable variations:

- a) for interruptible measuring systems
either significant faults do not occur or checking facilities detect a malfunctioning and act upon in it accordance with 4.3 when significant faults occur
- b) for non-interruptible measuring systems,
no significant faults occur.

A.11.7. Surges on signal, data and control lines

Test method:	Electrical surges on signal, data and control lines
Object of the test	To verify compliance with the provisions in 4.1.1 under conditions where electrical surges are superimposed on the mains voltage and - if applicable - on input/output and communication ports (...)
References:	IEC 61000-6-1 (2005-03) Generic Standards Immunity for residential, commercial and light-industrial environments (Severity Level 2) IEC 61000-6-2 (2005-01) Generic Standards Immunity for industrial environments (Severity Level 3) IEC 61000-4-5 (2005-11) Electromagnetic compatibility (EMC) – Part 4-5: Testing and Measurement techniques – Surge immunity test
Test procedure in brief	A surge generator shall be used with the performance characteristics as specified in the referred standard. The test consists of exposure to surges for which the rise time, pulse width, peak values of the output voltage/current on high/low impedance load and minimum time interval between two successive pulses are defined in the referred standard. The characteristics of the generator shall be verified before connecting the EUT. On signal, control and data lines at least 3 positive and 3 negative surges shall be applied. The injection network depends on the lines the surge is coupled into and is defined in the referred standard. The surges are applied during all the time necessary to perform the test; to that purpose more surges than indicated above may be necessary. During tests, the EUT shall be in operation, simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

		The following severity level shall be specified:		unit
Severity level (Installation class)		2		
Unsymmetrical (Unbalanced) lines	Line to line	0.5		kV
	Line to ground	1.0		kV
Symmetrical (Balanced) lines	Line to line	NA		kV
	Line to ground	1.0		kV
Shielded I/O and Communications lines	Line to line	NA		kV
	Line to ground	0.5		kV
Notes		1. Test on signal lines apply only for I/O, signal, data and control ports, with a cable length exceeding 30 meters (as specified by the manufacturer). 2. Indoors DC signal, data, and control cables (regardless of length) are exempt from this test.		

Maximum allowable variations:

a) For interruptible measuring systems, either significant faults do not occur or checking facilities detect a malfunctioning and act upon in it accordance with 4.3 when significant faults occur.

b) For non-interruptible measuring systems, no significant faults occur.

- In either a) or b) above, human intervention is permitted to put the EUT in operation after the test (e.g. replacing a fuse), provided that all relevant data is available after the human intervention.

A.11.8. Voltage dips, short interruptions and voltage variations on DC mains power

Test method	Voltage dips, short interruptions and voltage variations on DC input power ports.
Object of the test	To verify compliance with the provisions in 4.1.1 under conditions of voltage dips, voltage variations and short interruptions on DC input power ports.
References	IEC 61000-4-29 (2000-08) Electromagnetic compatibility (EMC) – Part 4-29: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations on DC input power port immunity tests
Test procedure in brief	<i>A test generator as defined in the referred standard shall be used. Before starting the tests, the performance of the generator shall be verified.</i> <i>The voltage dips and short interruptions shall be tested on the EUT, for each selected combination of test level and duration, with a sequence of three dips/interruptions with intervals of 10 s minimum between each test event.</i> The EUT shall be tested for each of the specified voltage variations, three times at 10 s intervals in the most representative operating modes. The disturbances are applied during all the time necessary to perform the test; to that purpose more disturbances than indicated above may be necessary. During tests, the EUT shall be in operation, simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

Test severities		The following severity level shall be specified:	unit
Voltage dips	Severity level	1 (test applicable only to E2 environments)	
	Test levels	40 and 70	% of the rated voltage
	Duration	0.1	s
Short interruptions	Test condition	High impedance and/or low impedance	
	Test levels	0	% of the rated voltage
	Duration	0.01	s
Voltage variations	Severity level	1	
	Test level	85 and 120	% of the rated voltage

	Duration	10	s
Notes	1) If the EUT is tested for short interruptions, it is unnecessary to test for other levels of the same duration, unless the immunity of the equipment is detrimentally affected by voltage dips of less than 70% of the rated voltage. 2) This test is not applicable to equipment powered by a road vehicle battery.		

Maximum allowable variations:

- a) for interruptible measuring systems
either significant faults do not occur or checking facilities detect a malfunctioning and act upon in it accordance with 4.3 when significant faults occur
- b) for non-interruptible measuring systems,
no significant faults occur.

A.11.9. Ripple on DC input power ports

Test method	Ripple on DC input power ports.
Object of the test	To verify compliance with the provisions in 4.1.1 under conditions of ripple on the low voltage DC power ports. This test does not apply to instruments connected to battery charger systems incorporating switch mode converters.
References	IEC 61000-4-17 (2002-07) Electromagnetic compatibility (EMC) Part 4-17: Testing and measurement techniques – Ripple on DC input power part immunity test.
Test procedure in brief	A test generator as defined in the referred standard shall be used. Before starting the tests, the performance of the generator shall be verified. The test consist subjecting electrical and electronic instruments to ripple voltages such as those generated by rectifier systems and/or auxiliary service battery chargers overlaying on DC power supply sources. The frequency of the ripple is the power frequency or its multiple 2, 3 or 6, as specified in the product specification. The waveform of the ripple, at the output of the test generator, has a sinusoid-linear character. The test shall be applied for at least 10 min or for the period time necessary to allow a complete verification of the EUT's operating performance. During tests, the EUT shall be in operation, simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

Test severities	The following severity level shall be specified:
Severity level:	1
Percentage of the nominal DC voltage ⁽¹⁾	2 ⁽¹⁾
Notes	1) The test level is a peak-to-peak voltage expressed as a percentage of the nominal DC voltage, U_{DC}. 2) This test is not applicable to equipment powered by a road vehicle battery.

Maximum allowable variations:	a) for interruptible measuring systems either significant faults do not occur or checking facilities detect a malfunctioning and act upon in it accordance with 4.3 when significant faults occur b) for non-interruptible measuring systems, no significant faults occur.
-------------------------------	--

A.11.10. Surges on AC and DC mains lines

Test method: Electrical surges on AC and DC mains power lines

Object of the test To verify compliance with the provisions in 4.1.1 under conditions where electrical surges are superimposed on the mains voltage.

- This test is not applicable to instruments connected to road vehicle batteries (see section A.12 for specific testing requirements for these instruments).
- This test is not applicable to indoor DC power supply networks.

References: IEC 61000-6-1 (2005-3) Generic Standards Immunity for residential, commercial and light-industrial environments.

IEC 61000-6-2 (2005-1) Generic Standards Immunity for industrial environments.

IEC 61000-4-5 (2005-11) Electromagnetic compatibility (EMC)
Part 4-5: Testing and Measurement techniques – Surge immunity test

Test procedure in brief A surge generator shall be used with the performance characteristics as specified in the referenced standard IEC 61000-4-5. The test consists of exposure to surges for which the rise time, pulse width, peak values of the output voltage/current on high/low impedance load and minimum time interval between two successive pulses are defined in the referenced standard.

The characteristics of the generator shall be verified before connecting the EUT.

On AC mains supply lines, at least 3 positive and 3 negative surges shall be applied synchronously with AC supply voltage in angles 0°, 90°, 180° and 270°. On any other kind of power supply, at least 3 positive and 3 negative surges shall be applied. The injection network depends on the lines the surge is coupled into and is defined in the referenced standard.

The surges are applied during all the time necessary to perform the test; to that purpose more surges than indicated above may be necessary.

During tests, the EUT shall be in operation, simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

Test severities	The following severity level shall be specified (both E1 and E2):	unit
Severity level (installation class)	3	
Line to line	1.0	kV
Line to ground	2.0	kV

- Maximum allowable variations:
- a) for interruptible measuring systems, either significant faults do not occur or checking facilities detect a malfunctioning and act upon in it accordance with 4.3 when significant faults occur.
 - b) for non-interruptible measuring systems, no significant faults occur.
- In either a) or b) above, human intervention is permitted to put the EUT in operation after the test (e.g. replacing a fuse), provided that all relevant data is available after the human intervention.

A.11.11. Radio frequency, immunity tests

A.11.11.1. Radiated, radio frequency, electromagnetic field of general origin

Test method:	Radiated electromagnetic fields
Object of the test:	To verify compliance with the provisions in 4.1.1 under conditions of electromagnetic fields.
References:	IEC 61000-6-1 (2005-3) Generic Standards Immunity for residential, commercial and light-industrial environments (Severity Level 2) IEC 61000-6-2 (2005-1) Generic Standards Immunity for industrial environments (Severity Level 3) IEC 61000-4-3 (2006-02) Electromagnetic compatibility (EMC) Part 4: Testing and measurement techniques, Section 3: Radiated, radio-frequency, electromagnetic field immunity test
Test procedure in brief:	The EUT shall be exposed to electromagnetic field strength as specified by the severity level and a field uniformity as defined by the referenced standard IEC 61000-4-3. The EM field can be generated in different facilities; however, the use of which is limited by the dimensions of the EUT and the frequency range of the facility. The frequency ranges to be considered are swept with the modulated signal, pausing to adjust the RF signal level or to switch oscillators and antennas as necessary. Where the frequency range is swept incrementally, the step size shall not exceed 1 % of the preceding frequency value. The dwell time of the amplitude modulated carrier at each frequency shall not be less than the time necessary for the EUT to be exercised and to respond, but shall in no case be less than 0.5 seconds. The sensitive frequencies (e.g. clock frequencies) shall be analyzed separately (Usually, these sensitive frequencies can be expected to be the frequencies emitted by the EUT). During tests, the EUT shall be in operation, and simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

Test severities:		One of the following severity levels shall be specified:		unit
Severity levels		2	3	
Frequency range	26 – 800 MHz (Note 2)	3	10	V/m
	80 – 800 MHz (Note 1)			
	960 –1400 MHz	3	10	V/m
Modulation		80 % AM, 1 kHz sine wave		
Notes		1) IEC 61000-4-3 (2006-02) only specifies test levels above 80 MHz. For frequencies in the lower range the test methods for conducted radio frequency disturbances are recommended (A.11.11.3) 2) However, for EUT having no mains or other input port available the lower limit of radiation test should be 26 MHz, taking into account that the test specified in A.11.11.3 cannot be applied (refer to Annex F of IEC 61000-4-3). In all other cases, both A.11.11.1 and A.11.11.2 shall apply.		

Maximum allowable variations:

- a) for interruptible measuring systems, either significant faults do not occur or checking facilities detect a malfunctioning and act upon in it accordance with 4.3 when significant faults occur.
- b) for non-interruptible measuring systems, no significant faults occur.

A.11.11.2. Radiated, radio frequency, electromagnetic fields specifically caused by digital telephones

Test method:	Radiated electromagnetic fields
Object of the test:	To verify compliance with the provisions in 4.1.1 under conditions of electromagnetic fields.
References:	IEC 61000-6-1 (2005-03) Generic Standards Immunity for residential, commercial and light-industrial environments (Severity Level 2) IEC 61000-6-2 (2005-01) Generic Standards Immunity for industrial environments (Severity Level 3) IEC 61000-4-3 (2006-02) Electromagnetic compatibility (EMC) Part 4: Testing and measurement techniques, Section3: Radiated, radio-frequency, electromagnetic field immunity test
Test procedure in brief:	The EUT shall be exposed to electromagnetic field strength as specified by the severity level and a field uniformity as defined by the referenced standard IEC 61000-4-3. The EM field can be generated in different facilities; however, the use of which is limited by the dimensions of the EUT and the frequency range of the facility. The frequency ranges to be considered are swept with the modulated signal, pausing to adjust the RF signal level or to switch oscillators and antennas as necessary. Where the frequency range is swept incrementally, the step size shall not exceed 1 % of the preceding frequency value. The dwell time of the amplitude modulated carrier at each frequency shall not be less than the time necessary for the EUT to be exercised and to respond, but shall in no case be less than 0.5 seconds. The sensitive frequencies (e.g. clock frequencies) shall be analyzed separately (Usually, these sensitive frequencies can be expected to be the frequencies emitted by the EUT). During tests, the EUT shall be in operation, and simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate. During tests, the EUT shall be in operation, simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

Test severities:		The following severity level shall be specified:	unit
Severity level:		3	
Frequency range	800 - 960 Mhz	10	V/m
	1400 – 2000 MHz	10	V/m
Modulation		80 % AM, 1 kHz sine wave	

Maximum allowable variations:

- a) for interruptible measuring systems, either significant faults do not occur or checking facilities detect a malfunctioning and act upon in it accordance with 4.3 when significant faults occur.
- b) for non-interruptible measuring systems, no significant faults occur .

A.11.11.3. Conducted radio frequency fields

Test method: Conducted electromagnetic fields

Object of the test: To verify compliance with the provisions in 4.1.1 under conditions of electromagnetic fields.

References: IEC 61000-6-1 (2005-3) Generic Standards Immunity for residential, commercial and light-industrial environments (Severity Level 2)
IEC 61000-6-2 (2005-1) Generic Standards Immunity for industrial environments (Severity Level 3)
IEC 61000-4-6 (2006-05) Electromagnetic compatibility (EMC) Part 4: Testing and measurement techniques, Section 6: Immunity to conducted disturbances, induced by radio frequency fields.

Test procedure in brief: Radio frequency EM current, simulating the influence of EM fields shall be coupled or injected into power ports and I/O ports of the EUT using coupling/decoupling devices as defined in the referenced standard IEC 61000-4-6.

The performance of the test equipment consisting of an RF generator, (de-)coupling devices, attenuators, etc. shall be verified.

During tests, the EUT shall be in operation, and simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

Test severities:	One of the following severity levels shall be specified:		unit
Severity levels	2	3	
RF amplitude (50 Ω)	3	10	V (e.m.f.)
Frequency range	0.15 – 80		MHz
Modulation	80 % AM, 1 kHz sine wave		
Notes:	Test on signal lines apply only for I/O signal, data and control ports, with a cable length exceeding 3 meters (as specified by the manufacturer).		

Maximum allowable variations:

a) for interruptible measuring systems
either significant faults do not occur or checking facilities detect a malfunctioning and act upon in it accordance with 4.3 when significant faults occur

b) for non-interruptible measuring systems,
no significant faults occur

A.12. Tests for power from road vehicle battery

A.12.1. General

For electronic devices powered by the on-board battery of a road vehicle, a series of special tests for disturbances associated with the power supply are given in **A.12.2 and A.12.3** of this Recommendation. These tests are based on the standards series ISO 7637. In accordance with clause 4 of ISO 7637-1 (2002), this series of standards “provides a basis for mutual agreement between vehicle manufacturers and component suppliers, intended to assist rather than restrict them.”

Electronic devices that are designed to be mounted onboard a road vehicle can normally be mounted in any kind of vehicle. Therefore, in **A.12.2 and A.12.3** of this Recommendation, only the highest severity level is indicated as the preferred level.

A.12.2. Voltage variations

Test method	Variation in supply voltage
Object of the test	To verify compliance with the provisions in 4.1.1 under conditions of varying battery voltage
References	The upper limits specified in this clause (16 V and 32 V) are in accordance with ISO/FDIS 16750-2:2003 Road vehicles – Environmental conditions and testing for electrical and electronic equipment; Part 2: Electrical loads. The lower limits (9 V and 16 V) are in accordance with ISO/FDIS 16750-2:2003 code C, respectively code F. For specifications of the power supply used during the test to simulate the battery, refer to ISO 7637-2 (1990), clause 4.4, Road vehicles - electrical disturbance by conducting and coupling, Part 2: Commercial vehicles with nominal 24 V supply voltage - Electrical transient conduction along supply lines only, or ISO/DIS CD 7637-2.3, clause 5.4, Road vehicles – electrical disturbance by conducting and coupling – Part 2: Electrical transient conducting along supply lines only.
Test procedure	The test consists of exposure to the specified power supply condition for a period sufficient for achieving temperature stability and for performing the required measurements. If a standard power supply (with sufficient current capacity) is used in bench testing to simulate the battery, it is important that the low internal impedance of the battery also be simulated. The continuous supply source shall have an internal resistance R_i less than $0.01\ \Omega$ dc and an internal impedance $Z_i = R_i$ for frequencies less than 400 Hz. During tests, the EUT shall be in operation, simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

Test severities	The following severity level shall be specified:		
Severity level	1		
Voltage	12 V battery	upper limit	16 V
	24 V battery	upper limit	32 V
			.
	12 V battery	lower limit	9 V
	24 V battery	lower limit	16 V

Maximum
allowable
variations:

At supply voltage levels between upper and lower limit:

- All functions shall operate as designed.
- All errors shall be within the maximum permissible errors.

A.12.3. Electrical transient conduction along supply lines

Test method	Electrical transient conduction along supply lines
Object of the test	To verify compliance with the provisions in 4.1.1 or under the following conditions: • transients due to a sudden interruption of current in a device connected in parallel with the device under test due to the inductance of the wiring harness (pulse 2a); • transients from DC motors acting as generators after the ignition is switched off (pulse 2b); • transients on the supply lines , which occur as a result of the switching processes (pulses 3a and 3b); • voltage reductions caused by energizing the starter-motor circuits of internal combustion engines (pulse 4)
References	(2004-06) Road vehicles - electrical disturbance by conducting and coupling. Part 2: Electrical transient conduction along supply lines only § 5.6.2: Test pulse 2a + 2b § 5.6.3: Test pulse 3a + 3b § 5.6.4: Test pulse 4
Test procedure in brief	The test consists of exposure to disturbances on the power supply by direct coupling on supply lines. During tests, the EUT shall be in operation, simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.

Test severities		The following severity level shall be specified:			
Severity levels		4			
Test pulse 2	12 V Battery	pulse 2a	U_s	+ 50 V	
		pulse 2b	U_s	+ 10 V	
	24 V Battery	pulse 2a	U_s	+ 50 V	
		pulse 2b	U_s	+ 20 V	
Test pulse 3	12 V Battery	pulse 3a	U_s	- 150 V	
		pulse 3b	U_s	+ 100 V	
	24 V Battery	pulse 3a	U_s	- 200 V	
		pulse 3b	U_s	+ 200 V	
Test pulse 4	12 V Battery		U_s	- 7 V	
	24 V Battery		U_s	- 16 V	

Maximum allowable variations:

- a) for interruptible measuring systems, either significant faults do not occur or checking facilities detect a malfunctioning and act upon in it accordance with 4.3 when significant faults occur.
- b) for non-interruptible measuring systems, no significant faults occur.

ANNEX B

INTERPRETATION, EXAMPLES AND POSSIBLE SOLUTIONS

(Infomative)

T.d.2

Main measuring systems used for direct selling to the public are:

- fuel dispensers,
- measuring systems on road tankers for the transport and delivery of domestic fuel oil.

T.g.1 Gas elimination devices

~~T.1.19~~ Gas separator

A gas elimination device used for continuously separating, and removing, any air or gases contained in the liquid.

~~T.1.20~~ Gas extractor

A gas elimination device used to extract air or gases accumulated in the supply line of the meter in the form of pockets that are no more than slightly mixed with the liquid.

~~T.1.21~~ Special gas extractor

A gas elimination device which, like the gas separator but under less stringent operating conditions, continuously separates any air or gases contained in the liquid, and which automatically stops the flow of liquid if there is a risk of air or gases, accumulated in the form of pockets no more than slightly mixed with the liquid, entering the meter.

~~T.1.22~~ Condenser tank

In pressurized liquefied gas measuring systems, a gas elimination device mainly consisting of a closed tank used to collect the gases contained in the liquid to be measured and to condense them before measuring.

T.i.1 A printing device which provides an indication at the end of the measurement is not an indicating device.

T.u.1 Components due to a verified or calibrated meter are notably linked to the resolution of its indicating device and to the periodic variation.

2.3.1 The manufacturer or approval applicant must state the rated conditions for the device they are submitting in the type approval application. See also Section 6.1.2.2.

[Section 2.7 has been completely rewritten in the DR.]

2.16.3

Any connection that may be provided for bypassing the meter shall be closed by means of blanking flanges. However, if the operating requirements make such a bypass necessary, it shall be closed either by means of a closing disc or a double closing device with a monitoring valve in between. It shall be possible to ensure closure by means of seals, or there shall be an automatic monitoring of the double block-and-bleed valve in the bypass giving an alarm signal in case of leakage in this valve.

The control valve of the double closing device mentioned before for pipework bypassing the meter, if provided, may be closed for safety reasons. In this case, any leakage shall be monitored by a pressure gauge located between the two shut off valves or by any other equivalent system.

2.9.2

National regulations can make a conversion device mandatory for some applications. In that case, the converted indications shall be indicated in normal use and the indications at metering conditions only on demand.

4.2.1 and 4.2.2

The requirements of 4.2.1 and 4.2.2 may be met by use of an external emergency power supply. When this is the case, the type approval certificate shall clearly specify this installation requirement. In this case the type approval certificate of the calculator with indicating device shall specify very clearly that this requirement applies to the measuring system in which the calculator and indicating device is intended to be included. The type approval certificate of the measuring system may specify tests to check this requirement during initial verification of the measuring system.

4.3.2.1

By applying security level B, as defined in ISO 6551 *Cabled transmission of electric and/or electronic pulsed data* this provision is presumed to be fulfilled.

4.3.3.1

Possible solutions to bullet 1:

- summing up all instruction and data codes and comparing the sum with a fixed value,
- line and column parity bits (LRC and VRC),
- cyclic redundancy check (CRC 16),
- double independent storage of data,

Possible solutions to bullet 2):

- write-read routine,
- conversion and reversion of codes,
- use of "safe coding" (check sum, parity bit),
- double storage.

4.3.3.2

This check may be carried out by such means as parity bit, check sum, or double storage.

4.3.4

During verification, determining that the checking facility of the indicating device is working can be achieved (for example), either:

- by disconnecting all or part of the indicating device, or
- by an action which simulates a failure in the display, such as using a test button.

4.3.4.3

Possible solutions for this section:

- for indicating devices using incandescent filaments or LEDs, measuring the current in the filaments;
- for indicating devices using fluorescent tubes, measuring the grid voltage;
- for indicating devices using electromagnetic shutters, checking the impact of each shutter;
- for indicating devices using multiplexed liquid crystals, output checking of the control voltage of segment lines and of common electrodes, so as to detect any disconnection or short circuit between control circuits.

5.1.3

This section describes the interpretation of the relevant articles of R117, related to the omitting of the gas elimination device in fuel dispensers, other than LPG dispensers, intended for installation in a system with a submerged pump.

When the measuring system is intended for installation in a centrally pumped system, or for a remote pump, the general provisions in 2.10 shall be applied, e.g. the provisions in point 2.10.1. Because of the pumped flow, the provisions of point 2.10.2 are also applicable.

As a general rule, a gas elimination device is to be installed.

However, the second paragraph of point 5.1.3 says:

“If it is not intended to install a gas elimination device, the manufacturer or installer has to prove that there is no risk of air intake or gas release. In this case, the minimum level in the storage tank must be automatically secured and any leakage shall be checked.”

When no gas elimination device is installed, these prescriptions may be fulfilled by applying all of the following provisions 1 to 8.

1. Air intake / Minimum level.

To secure automatically the minimum level in the storage tank, a level detection system shall be installed. This system prevents using the submerge pump when the liquid level reaches a minimum level above the inlet of the pump, so that there is no risk of air intake.

The minimum level that has to be respected is given by the following formula:

$$h \Rightarrow k.v^2 / 2.g$$

where:

h: minimum level of the liquid above the suction inlet of the pump [m]

v: maximum velocity of the liquid at the pump inlet [m/s]

g: acceleration of gravity [m/s²]

k: security factor; k is at least equal to 6

with k=6 the formula becomes:

$$h \Rightarrow 3v^2 / g$$

2. Gas release

Gas can be generated during shut down periods as a result of temperature drop.

If it can not be proven by calculation (see point 2.13.2) that the gaseous formation has a specific effect smaller than or equal to 1 % of the minimum measured quantity (see 10.2.2) than at least one of the following provisions shall be applied to assure that no released gas will be in the system at the start and during the delivery:

- 2.1 A detection system based on a pressure control device holds the pressure of the liquid always well above the vapour pressure.
- 2.2 Each delivery shall be delayed until the submerge pump has been running for at least 3 seconds.

3. Leak detection

A leak detection system shall be installed.

Detection of any leakage in the line shall result in stopping or preventing of any delivery.

The detection system of 2.1 can fulfil the leak detection function.

4. Pipeline construction

The pipelines between the pump unit and the dispenser are installed with a positive slope of at least 1 %. There shall be no significant portion with no slope.

No high points are allowed upstream of each dispenser, except for the ones needed for the connection with other dispensers.

5. Non-return valve.

At least one non-return valve shall be installed in the system. It is advisable to install a non-return valve upstream of every measurement transducer.

Note: this non-return valve shall not be likely to create gaseous formations.

6. Security of the devices

All the devices mentioned shall be in “positive” security so that no delivery is possible if one of these devices fail.

It shall be possible to check if the electronic devices (e.g. by simulation) are functioning correctly.

7. Type approval

The type approval certificate of the fuel dispenser shall clearly describe the above provisions 1 to 7 that have to be followed to allow the omitting of the gas elimination device.

8. Initial verification

The initial verification of the fuel dispenser shall include examination on site of use with respect to the above provisions:

- testing the positive security of all the devices,
- checking the correct functioning of the electronic devices by simulation,
- checking that the prescription for the minimum level is fulfilled,
- checking the presence of a leak detection system,
- if applicable, checking the delay time of delivery for each dispenser,
- checking the slope of the pipes on drawings.

5.4.2

Possible solutions:

A pressure maintaining device, located downstream of the meter, ensures that the product in the meter remains in a liquid state during the measurement. The necessary pressure could be maintained either at a fixed value or at a value adjusted to suit the measurement conditions.

When the pressure is maintained at a fixed value, this value shall be at least equal to the vapor pressure of the product at a temperature 15 °C above the highest possible operating temperature. It shall be possible to protect the adjustment of the pressure maintaining device with a seal.

When the pressure is adjusted to suit the measurement conditions, this pressure shall exceed the vapor pressure of the liquid during the measurement by at least 100 kPa (1 bar). This adjustment shall be automatic.

5.10.2.1.1

It is not allowed the use of more than two stored transactions, ready to be paid in the kiosk. A fuel dispenser may be authorized for a next delivery before the previous transaction on the same dispenser has been settled. This means that a maximum of two deliveries are stored and the dispenser cannot be authorized for a next delivery until one of them has been settled.

6.1.5.2.4

Examples:

It is necessary to make a distinction between a pattern of a meter intended to measure several products (in the same measuring system) and a pattern of a meter of which different copies may be used for measuring different products (in different measuring systems), each copy being intended to measure a given product only.

For example, meter A may be intended to measure diesel and gasoline alternatively, whereas meter B is intended to measure either diesel or gasoline. Both meters will be subject to accuracy tests with diesel and with gasoline at the time of pattern approval. For meter A, the error curves for gasoline and for diesel shall both be within the maximum permissible errors as specified in 3.1.2.

For meter B, the error curves for diesel on the one hand, and for gasoline on the other hand, shall satisfy the maximum permissible errors; unlike meter A, however, these error curves may be determined using different copies of the meter, or alternatively on the same copy whose adjustment (or correction parameters) has been modified between the test with diesel and the test with gasoline.

Copies of meter A will bear the mention of diesel and gasoline on their data plate and they may also be used to measure mixtures of diesel and gasoline in any proportion.

Copies of meter B will bear either the mention "diesel" or the mention "gasoline" and shall be used for measuring the corresponding product exclusively.

The preliminary verification of pattern A copies may be carried out with either diesel or gasoline, indifferently (with, if appropriate, a reduction of the maximum permissible errors range).

In general, the preliminary verification of pattern B copies will be carried out with the liquid intended to be measured; however, it may be carried out with the other liquid provided that the maximum permissible errors have been shifted. The value of shifting shall be determined at the time of pattern evaluation by evaluating the deviation between the error curves determined with diesel and with gasoline, on the same meter, without modification of the adjustment. These deviations shall be reproducible, from one copy of the meter to another. To check this, it is necessary to carry out accuracy tests on several instruments.

6.1.10

For example, it is not necessary to perform the expansion test of a hose in a fuel dispenser when the hose in this measuring system is identical to the hose equipping another measuring system already approved with the same minimum measured quantity.

6.2.2.1 (bullet 4) states:

- for measuring systems on road tankers, the gas elimination device shall be tested for the removal of air pockets by emptying the supply tank (compartment) during a delivery (product depletion test)

On multiple-compartment road tankers, only one compartment needs to be emptied to satisfy this requirement.

A.6.2

Tests at the limits of pressure are not needed if the maximum liquid pressure is below 10 bar or if the pressure effect can be calculated and is within the maximum permissible errors. In other cases tests are to be performed at liquid pressures to within 10 bar of the high and low limit of liquid pressure.

Test at the limits of viscosity are to be carried out to within:

- 1 mPa.s for limits between 0 and 4 mPa.s,
- 2 mPa.s for limits between 4 and 10 mPa.s,
- 10 mPa.s for limits between 10 and 100 mPa.s,
- 100 mPa.s for limits between 100 and 1000 mPa.s,
- 1000 mPa.s for limits between 1000 and 10000 mPa.s.

Tests at the limits of liquid density are to be performed to within 100 kg/m³ of the high and low limit of liquid density.

Where the measuring system is intended to measure liquid quantities at temperatures from – 5 °C to + 35 °C, only one accuracy test at one temperature between – 5 °C and + 35 °C is required.

A.6.4

A few disturbance configurations are provided in the case that flow disturbance testing is performed:

- Two elbows in the same plane upstream the meter or the measurement transducer,
- Two elbows in the same plane upstream the meter or the measurement transducer and two elbows in the same plane upstream the meter or the measurement transducer,
- A locked propeller upstream the meter or the measurement transducer,
- A locked propeller downstream the meter or the measurement transducer,
- A valve upstream the meter or the measurement transducer in several positions (90°, 80°, 65°, 45°).

If necessary, additional disturbance configurations may be defined by the technology of the meter.

[this is the end of Annex B]